

B O N N E V I L L E P O W E R A D M I N I S T R A T I O N

BP-22 Rate Proceeding

Final Proposal

Generation Inputs Study Documentation

BP-22-FS-BPA-06A

July 2021



GENERATION INPUTS STUDY DOCUMENTATION

TABLE OF CONTENTS

| | Page |
|--|------------|
| COMMONLY USED ACRONYMS AND SHORT FORMS | iii |
| TABLES | 1 |
| Table 1: Inter-Business Line Allocations..... | 3 |
| Table 2.1: Forecast of Installed Generation Capacity for the FY 2022-2023 Balancing Reserve Capacity Quantity Forecast..... | 4 |
| Table 2.2: VER Facilities in FY 2022-2023 Balancing Reserve Capacity Quantity Forecast..... | 5 |
| Table 2.3: Solar Day-of-Year and Time-of-Day Data Calculations..... | 6 |
| Table 2.4: Total Irradiance Calculations | 7 |
| Table 2.5: Irradiance to Power Conversion Calculations | 8 |
| Table 2.6: Point-Source Scaling PV Calculations..... | 9 |
| Table 2.7: Incremental Standard Deviation Calculation Example | 10 |
| Table 2.8: Load Regulation Incremental Reserves Example..... | 11 |
| Table 2.9: Total Balancing Reserve Capacity Requirement (Values in MW) for FY2022-2023 Balancing Reserve Capacity Quantity Forecast | 12 |
| Table 2.10: Load Balancing Reserve Capacity Requirement (Values in MW) for FY2022-2023 Balancing Reserve Capacity Quantity Forecast | 13 |
| Table 2.11: Wind Balancing Reserve Capacity Requirement (Values in MW) for FY2022-2023 Balancing Reserve Capacity Quantity Forecast | 14 |
| Table 2.12: Non-Federal Thermal Balancing Reserve Capacity Requirement (Values in MW) for FY2022-2023 Balancing Reserve Capacity Quantity Forecast..... | 15 |
| Table 2.13: Solar Balancing Reserve Capacity Requirement (Values in MW) for FY2022-2023 Balancing Reserve Capacity Quantity Forecast | 16 |
| Table 2.14: FCRPS Balancing Reserve Capacity Requirement (Values in MW) for FY2022-2023 Balancing Reserve Capacity Quantity Forecast | 17 |
| Table 3.1: Balancing Area Net Load and Generation..... | 18 |
| Table 3.2: Forecst Operating Reserve Obligation..... | 19 |
| Table 4.1: 1-Hour Capacity of Federal System Resources for FY 2022 and FY 2023 Adjusted for Transmission Losses..... | 20 |
| Table 4.2: Capacity Costs..... | 21 |
| Table 4.3: Embedded Cost Calculation | 22 |
| Table 4.4: Super Peak Market Prices for FY 2022 by Month and Water Year | 23 |
| Table 4.5: Super Peak Market Prices for FY 2023 by Month and Water Year | 24 |
| Table 4.6: Graveyard Market Prices for FY 2022 by Month and Water Year | 25 |
| Table 4.7: Graveyard Market Prices for FY 2023 by Month and Water Year | 26 |
| Table 4.8: Variable Costs Sub-Categories of Stand Ready Costs from the GARD Model..... | 27 |
| Table 4.9: Variable Costs Components for Reserves Under 99.7% Level of Service with Self Supply of Generation Imbalance..... | 28 |
| Table 4.10: GARD Stand-ready Costs and EIM Cost Offsets | 29 |

| | | |
|-------------|--|----|
| Table 4.11: | 7HA.02 SCCT Frame Annual Costs..... | 30 |
| Table 4.12: | Cost of Capacity Calculation..... | 31 |
| Table 4.13: | Revenue Forecast..... | 32 |
| Table 5.1: | Synchronous Condenser Projected Motoring Hours, Hourly Energy Consumption and Energy Costs..... | 33 |
| Table 5.2: | Determination of Synchronous Condenser Plant Modification Costs | 34 |
| Table 5.3: | Summary of Synchronous Condenser Costs..... | 35 |
| Table 6.1: | Estimated Costs of "Generation Drop" of Unit 22, 23, or 24 at the Grand Coulee Third Powerhouse..... | 36 |
| Table 7.1: | Redispatch Costs FY 2016 to August 2020 | 37 |
| Table 8.1: | Load Factor Calculation for Station Service Energy Use Analysis..... | 38 |
| Table 8.2: | Calculation of Station Service Use and Cost..... | 39 |

COMMONLY USED ACRONYMS AND SHORT FORMS

| | |
|------------|---|
| AAC | Anticipated Accumulation of Cash |
| ACNR | Accumulated Calibrated Net Revenue |
| ACS | Ancillary and Control Area Services |
| AF | Advance Funding |
| AFUDC | Allowance for Funds Used During Construction |
| AGC | automatic generation control |
| aMW | average megawatt(s) |
| ANR | Accumulated Net Revenues |
| ASC | Average System Cost |
| BAA | Balancing Authority Area |
| BiOp | Biological Opinion |
| BPA | Bonneville Power Administration |
| BPAP | Bonneville Power Administration Power |
| BPAT | Bonneville Power Administration Transmission |
| Bps | basis points |
| Btu | British thermal unit |
| CAISO | California Independent System Operator |
| CIP | Capital Improvement Plan |
| CIR | Capital Investment Review |
| CDQ | Contract Demand Quantity |
| CGS | Columbia Generating Station |
| CHWM | Contract High Water Mark |
| CNR | Calibrated Net Revenue |
| COB | California-Oregon border |
| COE | U.S. Army Corps of Engineers |
| COI | California-Oregon Intertie |
| Commission | Federal Energy Regulatory Commission |
| Corps | U.S. Army Corps of Engineers |
| COSA | Cost of Service Analysis |
| COU | consumer-owned utility |
| Council | Northwest Power and Conservation Council (see also "Council") |
| COVID-19 | coronavirus disease 2019 |
| CP | Coincidental Peak |
| CRAC | Cost Recovery Adjustment Clause |
| CRFM | Columbia River Fish Mitigation |
| CSP | Customer System Peak |
| CT | combustion turbine |
| CWIP | Construction Work in Progress |
| CY | calendar year (January through December) |
| DD | Dividend Distribution |
| DDC | Dividend Distribution Clause |
| dec | decrease, decrement, or decremental |
| DERBS | Dispatchable Energy Resource Balancing Service |

| | |
|---------|---|
| DFS | Diurnal Flattening Service |
| DNR | Designated Network Resource |
| DOE | Department of Energy |
| DOI | Department of Interior |
| DSI | direct-service industrial customer or direct-service industry |
| DSO | Dispatcher Standing Order |
| EE | Energy Efficiency |
| EESC | EIM Entity Scheduling Coordinator |
| EIM | Energy imbalance market |
| EIS | Environmental Impact Statement |
| ELMP | Extended Locational Marginal Pricing |
| EN | Energy Northwest, Inc. |
| ESA | Endangered Species Act |
| ESS | Energy Shaping Service |
| e-Tag | electronic interchange transaction information |
| FBS | Federal base system |
| FCRPS | Federal Columbia River Power System |
| FCRTS | Federal Columbia River Transmission System |
| FELCC | firm energy load carrying capability |
| FERC | Federal Energy Regulatory Commission |
| FMM-IIE | Fifteen Minute Market – Instructed Imbalance Energy |
| FOIA | Freedom of Information Act |
| FORS | Forced Outage Reserve Service |
| FPS | Firm Power and Surplus Products and Services |
| FPT | Formula Power Transmission |
| FRP | Financial Reserves Policy |
| F&W | Fish & Wildlife |
| FY | fiscal year (October through September) |
| G&A | general and administrative (costs) |
| GARD | Generation and Reserves Dispatch (computer model) |
| GDP | Gross Domestic Product |
| GI | generation imbalance or generator interconnection |
| GMS | Grandfathered Generation Management Service |
| GSP | Generation System Peak |
| GSR | Generation Supplied Reactive |
| GRSPs | General Rate Schedule Provisions |
| GTA | General Transfer Agreement |
| GWh | gigawatthour |
| HLH | Heavy Load Hour(s) |
| HOSS | Hourly Operating and Scheduling Simulator (computer model) |
| HYDSIM | Hydrosystem Simulator (computer model) |
| IE | Eastern Intertie |
| IIE | Instructed Imbalance Energy |
| IM | Montana Intertie |
| inc | increase, increment, or incremental |

| | |
|------------------|--|
| IOU | investor-owned utility |
| IP | Industrial Firm Power |
| IPR | Integrated Program Review |
| IR | Integration of Resources |
| IRD | Irrigation Rate Discount |
| IRM | Irrigation Rate Mitigation |
| IRPL | Incremental Rate Pressure Limiter |
| IS | Southern Intertie |
| kcf ^s | thousand cubic feet per second |
| KSI | key strategic initiative |
| kW | kilowatt |
| kWh | kilowatthour |
| LAP | Load Aggregation Point |
| LDD | Low Density Discount |
| LGIA | Large Generator Interconnection Agreement |
| LLH | Light Load Hour(s) |
| LMP | Locational Marginal Price |
| LPP | Large Project Program |
| LT | long term |
| LTF | Long-term Firm |
| Maf | million acre-feet |
| Mid-C | Mid-Columbia |
| MMBtu | million British thermal units |
| MNR | Modified Net Revenue |
| MRNR | Minimum Required Net Revenue |
| MW | megawatt |
| MWh | megawatthour |
| NCP | Non-Coincidental Peak |
| NEPA | National Environmental Policy Act |
| NERC | North American Electric Reliability Corporation |
| NFB | National Marine Fisheries Service (NMFS) Federal Columbia River Power System (FCRPS) Biological Opinion (BiOp) |
| NLSL | New Large Single Load |
| NMFS | National Marine Fisheries Service |
| NOAA Fisheries | National Oceanographic and Atmospheric Administration Fisheries |
| NOB | Nevada-Oregon border |
| NORM | Non-Operating Risk Model (computer model) |
| NWPA | Northwest Power Act/Pacific Northwest Electric Power Planning and Conservation Act |
| NP-15 | North of Path 15 |
| NPCC | Northwest Power and Conservation Council |
| NPV | net present value |
| NR | New Resource Firm Power |
| NRFS | NR Resource Flattening Service |

| | |
|-------------|--|
| NRU | Northwest Requirements Utilities |
| NT | Network Integration |
| NTSA | Non-Treaty Storage Agreement |
| NUG | non-utility generation |
| NWPP | Northwest Power Pool |
| OATT | Open Access Transmission Tariff |
| O&M | operations and maintenance |
| OATI | Open Access Technology International, Inc. |
| ODE | Over Delivery Event |
| OS | Oversupply |
| OY | operating year (August through July) |
| PDCI | Pacific DC Intertie |
| PF | Priority Firm Power |
| PFp | Priority Firm Public |
| PFx | Priority Firm Exchange |
| PNCA | Pacific Northwest Coordination Agreement |
| PNRR | Planned Net Revenues for Risk |
| PNW | Pacific Northwest |
| POD | Point of Delivery |
| POI | Point of Integration or Point of Interconnection |
| POR | Point of Receipt |
| PPC | Public Power Council |
| PRSC | Participating Resource Scheduling Coordinator |
| PS | Power Services |
| PSC | power sales contract |
| PSW | Pacific Southwest |
| PTP | Point-to-Point |
| PUD | public or people's utility district |
| RAM | Rate Analysis Model (computer model) |
| RAS | Remedial Action Scheme |
| RCD | Regional Cooperation Debt |
| RD | Regional Dialogue |
| RDC | Reserves Distribution Clause |
| REC | Renewable Energy Certificate |
| Reclamation | U.S. Bureau of Reclamation |
| REP | Residential Exchange Program |
| REPSIA | REP Settlement Implementation Agreement |
| RevSim | Revenue Simulation Model |
| RFA | Revenue Forecast Application (database) |
| RHWM | Rate Period High Water Mark |
| ROD | Record of Decision |
| RPSA | Residential Purchase and Sale Agreement |
| RR | Resource Replacement |
| RRS | Resource Remarketing Service |
| RSC | Resource Shaping Charge |

| | |
|-------------------------|--|
| RSS | Resource Support Services |
| RT1SC | RHWM Tier 1 System Capability |
| RTD-IIE | Real-Time Dispatch – Instructed Imbalance Energy |
| RTIEO | Real-Time Imbalance Energy Offset |
| SCD | Scheduling, System Control, and Dispatch Service |
| SCADA | Supervisory Control and Data Acquisition |
| SCS | Secondary Crediting Service |
| SDD | Short Distance Discount |
| SILS | Southeast Idaho Load Service |
| Slice | Slice of the System (product) |
| SMCR | Settlements, Metering, and Client Relations |
| SP-15 | South of Path 15 |
| T1SFCO | Tier 1 System Firm Critical Output |
| TC | Tariff Terms and Conditions |
| TCMS | Transmission Curtailment Management Service |
| TDG | Total Dissolved Gas |
| TGT | Townsend-Garrison Transmission |
| TOCA | Tier 1 Cost Allocator |
| TPP | Treasury Payment Probability |
| TRAM | Transmission Risk Analysis Model |
| Transmission System Act | Federal Columbia River Transmission System Act |
| Treaty | Columbia River Treaty |
| TRL | Total Retail Load |
| TRM | Tiered Rate Methodology |
| TS | Transmission Services |
| TSS | Transmission Scheduling Service |
| UAI | Unauthorized Increase |
| UDE | Under Delivery Event |
| UFE | unaccounted for energy |
| UFT | Use of Facilities Transmission |
| UIC | Unauthorized Increase Charge |
| UIE | Uninstructed Imbalance Energy |
| ULS | Unanticipated Load Service |
| USACE | U.S. Army Corps of Engineers |
| USFWS | U.S. Fish & Wildlife Service |
| VER | Variable Energy Resource |
| VERBS | Variable Energy Resource Balancing Service |
| VOR | Value of Reserves |
| VR1-2014 | First Vintage Rate of the BP-14 rate period (PF Tier 2 rate) |
| VR1-2016 | First Vintage Rate of the BP-16 rate period (PF Tier 2 rate) |
| WECC | Western Electricity Coordinating Council |
| WSPP | Western Systems Power Pool |

This page intentionally left blank.

TABLES

This page intentionally left blank.

Table 1
Inter-Business Line Allocations

| | A | B | C |
|--|--|---|--|
| | Generation Inputs | Annual Average FY 2022-2023 Reserve Quantity Forecast (MW) | Annual Average FY 2022-2023 Revenue Forecast (\$) |
| 1 Reserve Forecast | | | |
| 2 Balancing for Load | | | |
| 3 | Balancing for Non-Fed Generation | | \$ 28,814,146 |
| 4 | Balancing for Federal Generation | 23 | \$ (2,268,039) |
| 5 | Balancing for All Generation | 389 | \$ 31,082,185 |
| 6 | Operating Reserves | | \$ 37,894,455 |
| 7 | Operating Reserves - Spinning | 237 | \$ 22,924,157 |
| 8 | Operating Reserves - Supplemental | 237 | \$ 14,970,298 |
| 9 | Reserves Total (lines 2+3+6) | | \$ 90,790,277 |
| 10 | | | |
| 11 Other Forecasts | | | |
| 12 | Synchronous Condensing | | \$ 922,844 |
| 13 | Generation Dropping | | \$ 364,955 |
| 14 | Redispatch | | \$ 370,000 |
| 15 | Segmentation of COE/BOR | | \$ 9,502,000 |
| 16 | Station Service | | \$ 2,295,181 |
| 17 | Other Total (lines 12-17) | | \$ 13,454,980 |
| 18 | | | |
| 19 | Generation Inputs Composite (lines 9+18-17) | | \$ 116,104,375 |
| 20 | Generation Inputs Non-Slice (line 17) | | \$ 8,186,897 |
| 21 | | | |
| 22 | Total Generation Inputs Credit Forecast (lines 20+21) | | \$ 104,245,257 |

Table 2.1
**Forecast of Installed Generation Capacity for the FY 2022-2023 Balancing
Reserve Capacity Quantity Forecast (Values in MW)**

| | A | B | C | D | E |
|----|------------------|--------------|-----------|---------------------|--------------|
| | | WIND | SOLAR | NON-FEDERAL THERMAL | FCRPS |
| 1 | Oct-21 | 2,930 | 89 | 1,548 | 3,384 |
| 2 | Nov-21 | 2,830 | 89 | 1,548 | 3,384 |
| 3 | Dec-21 | 2,830 | 89 | 1,548 | 3,384 |
| 4 | Jan-22 | 2,830 | 89 | 1,548 | 3,384 |
| 5 | Feb-22 | 2,830 | 89 | 1,548 | 3,384 |
| 6 | Mar-22 | 2,830 | 89 | 1,548 | 3,384 |
| 7 | Apr-22 | 2,830 | 89 | 1,548 | 3,384 |
| 8 | May-22 | 2,830 | 89 | 1,548 | 3,384 |
| 9 | Jun-22 | 2,830 | 89 | 1,548 | 3,384 |
| 10 | Jul-22 | 2,830 | 89 | 1,548 | 3,384 |
| 11 | Aug-22 | 2,830 | 89 | 1,548 | 3,384 |
| 12 | Sep-22 | 2,830 | 89 | 1,548 | 3,384 |
| 13 | Oct-22 | 2,830 | 109 | 1,548 | 3,384 |
| 14 | Nov-22 | 2,830 | 109 | 1,548 | 3,384 |
| 15 | Dec-22 | 2,830 | 109 | 1,548 | 3,384 |
| 16 | Jan-23 | 2,830 | 109 | 1,548 | 3,384 |
| 17 | Feb-23 | 2,830 | 109 | 1,548 | 3,384 |
| 18 | Mar-23 | 2,830 | 109 | 1,548 | 3,384 |
| 19 | Apr-23 | 2,830 | 109 | 1,548 | 3,384 |
| 20 | May-23 | 2,830 | 109 | 1,548 | 3,384 |
| 21 | Jun-23 | 2,830 | 109 | 1,548 | 3,384 |
| 22 | Jul-23 | 2,830 | 109 | 1,548 | 3,384 |
| 23 | Aug-23 | 2,830 | 109 | 1,548 | 3,384 |
| 24 | Sep-23 | 2,830 | 109 | 1,548 | 3,384 |
| 25 | BP-22 AVG | 2,834 | 99 | 1,548 | 3,384 |

Table 2.2
VER Facilities in FY 2022-2023
Balancing Reserve Capacity Quantity Forecast

| A | B | C | D | E | |
|----|--------------------------|-------------------------|----------|------------------|----------------------|
| | Project Name | Nameplate Capacity (MW) | VER Type | County, State | Start Month and Year |
| 1 | Vansycle | 25 | WIND | Umatilla, OR | Oct-98 |
| 2 | Stateline | 90 | WIND | Walla Walla, WA | Dec-01 |
| 3 | Condon | 50 | WIND | Gilliam, OR | Jun-02 |
| 4 | Blue Sky/Hopkins Ridge | 157 | WIND | Columbia, WA | Nov-05 |
| 5 | White Creek | 204 | WIND | Klickitat, WA | Oct-07 |
| 6 | Nine Canyon I-II | 50 | WIND | Benton, WA | May-08 |
| 7 | Arlington Wind | 103 | WIND | Gilliam, OR | Dec-08 |
| 8 | Willow Creek | 72 | WIND | Morrow, OR | Jan-09 |
| 9 | Wheatfield Wind | 97 | WIND | Gilliam, OR | Mar-09 |
| 10 | Windy Flats Dooley | 262 | WIND | Klickitat, WA | Nov-09 |
| 11 | Harvest-White Creek III | 100 | WIND | Klickitat, WA | Dec-09 |
| 12 | Combine Hills | 63 | WIND | Umatilla, OR | Jan-10 |
| 13 | Linden Ranch | 50 | WIND | Klickitat, WA | Jun-10 |
| 14 | Coastal Energy Wind | 6 | WIND | Grays Harbor, WA | Jun-10 |
| 15 | Kittitas Valley | 101 | WIND | Kittitas, WA | Nov-10 |
| 16 | Patu (Oregon Trail Wind) | 10 | WIND | Sherman, OR | Nov-10 |
| 17 | North Hurlburt | 266 | WIND | Gilliam, OR | Aug-11 |
| 18 | Lower Snake Wind | 343 | WIND | Garfield, WA | Jan-12 |
| 19 | South Hurlburt | 290 | WIND | Gilliam, OR | Jun-12 |
| 20 | HorseShoe Bend | 291 | WIND | Morrow, OR | Aug-12 |
| 21 | Outback Solar | 5 | SOLAR | Lake, OR | Sep-12 |
| 22 | Starvation Solar | 10 | SOLAR | Harney, OR | Dec-19 |
| 23 | Fort Rock Solar | 10 | SOLAR | Lake, OR | Mar-20 |
| 24 | West Hines Solar | 10 | SOLAR | Harney, OR | Jun-20 |
| 25 | Alkali Solar | 10 | SOLAR | Lake, OR | Jun-20 |
| 26 | Fort Rock IV Solar | 10 | SOLAR | Lake, OR | Jun-20 |
| 27 | Rock Garden Solar | 10 | SOLAR | Lake, OR | Jun-20 |
| 28 | Riley Solar | 10 | SOLAR | Harney, OR | Jul-20 |
| 29 | Suntex Solar | 10 | SOLAR | Harney, OR | Jul-20 |
| 30 | Wheatridge Wind 1 | 100 | WIND | Morrow, OR | Nov-20 |
| 31 | Wheatridge Wind 2 | 200 | WIND | Morrow, OR | Nov-20 |
| 32 | Horn Rapids Solar | 3.2 | SOLAR | Benton, WA | Nov-20 |
| 33 | Tygh Valley Solar | 20 | SOLAR | Wasco, OR | Oct-22 |

Table 2.3
Solar Day-of-Year and Time-of-Day Data Calculations

| | | |
|----|---|--------------------------------|
| 1 | Equation of Time | [Equation 2.27 in Reference 1] |
| 2 | $ET = 9.87 \sin(2B) - 7.53 \cos(B) - 1.5 \sin(B)$ where $B = \frac{360(n-81)}{364^\circ}$ n = nth day of year | |
| 3 | Local Solar Time | [Equation 2.26 in Reference 1] |
| 4 | $ST = lst + ET + 4(lon_{std} - lon_{local})$ where lon_{std} is the standard time meridian (120°) lon_{local} is the longitude of the plant 4 is in units of minutes/degree | |
| 5 | Degree from Solar Noon | [Equation 2.25 in Reference 1] |
| 6 | $h_s = \frac{ST - 12 * 60}{4}$ | |
| 7 | Declination Angle | [Equation 2.23 in Reference 1] |
| 8 | $\delta_s = \sin^{-1} \left(23.45^\circ \cdot \sin \left(\frac{360 \cdot (284 + n)}{365^\circ} \right) \right)$ where n =nth day of year | |
| 9 | Solar Altitude Angle | [Equation 2.28 in Reference 1] |
| 10 | $\alpha = \sin^{-1}(\sin(lat_{local}) \sin(\delta_s) + \cos(lat_{local}) \cos(\delta_s) \cos(h_s))$ where lat_{local} is the latitude of the plant | |
| 11 | Solar Azimuth Angle | [Equation 2.29 in Reference 1] |
| 12 | $a_s = \sin^{-1} \left(\frac{\cos(\delta_s) \sin(h_s)}{\cos(\alpha)} \right)$ | |
| 13 | Tracking Angle | [Equation 4.13 in Reference 2] |
| 14 | $\beta = \rho = \tan^{-1} \left(\frac{\sin(a_s)}{\tan(\alpha)} \right)$ | |
| 15 | Angle of Incidence | [Equation 4.14 in Reference 2] |
| 16 | $\theta_i = \cos^{-1} \left(\sqrt{1 - ((\cos(\alpha))^2 \cdot (\cos(a_s))^2)} \right)$ | |
| 17 | References: | |
| 18 | 1) Goswami, Dr. Y et al. (2000). Principles of Solar Engineering. New York: Taylor and Francis Group | |
| 19 | 2) Stine, W and Geyer, M (2001). Power From the Sun. Retrieved from http://www.powerfromthesun.net | |

Table 2.4
Total Irradiance Calculations

| | | |
|---|--|--------------------------------|
| 1 | Direct Normal component of Irradiance | [Equation 2.47 in Reference 1] |
| 2 | $I_{dn} = \cos(\theta_i) \cdot (\text{Direct Normal Sensor Data})$ | |
| 3 | Diffuse component of Irradiance | [Equation 2.49 in Reference 1] |
| 4 | $I_{df} = \left(\cos\left(\frac{\beta}{2}\right) \right)^2 \cdot (\text{Diffuse Sensor Data})$ | |
| 5 | Total Irradiance | |
| 6 | $I_t = I_{dn} + I_{df}$ | |
| 7 | | |
| 8 | Reference: | |
| 9 | 1) Goswami, Dr. Y et al. (2000). Principles of Solar Engineering. New York: Taylor and Francis Group | |

Table 2.5
Irradiance to Power Conversion Calculations

| | | |
|----|--|-----------------------------|
| 1 | Cell Temperature | [Equation 1 in Reference 4] |
| 2 | $cell\ temp = temp + I_t \cdot cell\ temp\ coef$ | |
| 3 | Temperature Coefficient | [Equation 8 in Reference 3] |
| 4 | $temp\ coef = 1 - temp\ coef_{static}(cell\ temp - 28)$ | |
| 5 | Predicted Power (DC) | [Equation 8 in Reference 3] |
| 6 | $PP = NP_{DC} \cdot Efficiency \cdot \frac{I_t}{1000} \cdot temp\ coef$ | |
| 7 | | |
| 8 | References: | |
| 9 | 3) Dobos, A (2013). PVWatts Technical Manual. NREL: https://www.nrel.gov/docs/fy14osti/60272.pdf | |
| 10 | 4) Alonso Garcia, M.C. and Balenzategui, J.L. (2004). Estimation of photovoltaic module yearly temperature and performance based on Nominal Operation Cell Temperature Calculations. | |

Table 2.6
Point-Source Scaling PV Calculations

| | | |
|---|---|---------------|
| 1 | Rolling Average Calculation | [Reference 5] |
| 2 | $RollingAvg(t) = average \left(data \left[t - \left(\frac{T}{2} - 1 \right) : t + \frac{T}{2} \right] \right)$ | |
| 3 | $T = 2 * round(\sqrt{400 \cdot NP_{DC}})$ | |
| 4 | | |
| 5 | Inverter Loading Ratio Adjustment | |
| 6 | $PP(PP > NP_{AC}) = NP_{AC}$ | |
| 7 | | |
| 8 | References: | |
| 9 | 5) Adapted from "A Wavelet-Based Variability Model (WVM for Solar PV Power Plants" by Matthew Lave, Jan Kleissl, and Joshua Stein, 2013, IEEE Transactions on Sustainable Energy, Volume 4, No. 2 | |

Table 2.7
Incremental Standard Deviation Calculation Example

| | |
|----|---|
| 1 | |
| 2 | Reg <i>inc</i> _{Load HE1} = Total Reg <i>inc</i> * R _{Load Reg HE1, Total Reg HE1} * S _{Load Reg HE1} / S _{TotalReg HE1} |
| 3 | Reg <i>inc</i> _{Wind HE1} = Total Reg <i>inc</i> * R _{Wind Reg HE1, Total Reg HE1} * S _{Wind Reg HE1} / S _{TotalReg HE1} |
| 4 | Reg <i>inc</i> _{Solar HE1} = Total Reg <i>inc</i> * R _{Solar Reg HE1, Total Reg HE1} * S _{Solar Reg HE1} / S _{TotalReg HE1} |
| 5 | Reg <i>inc</i> _{FCRPS HE1} = Total Reg <i>inc</i> * R _{FCRPS Reg HE1, Total Reg HE1} * S _{FCRPS Reg HE1} / S _{TotalReg HE1} |
| 6 | Reg <i>inc</i> _{Non-Fed Thermal HE1} = Total Reg <i>inc</i> * R _{Non-Fed Thermal Reg HE1, Total Reg HE1} * S _{Non-Fed Thermal Reg HE1} / S _{TotalReg HE1} |
| 7 | |
| 8 | Where: Reg is Regulating Reserves |
| 9 | HE1 is Hour Ending 1 |
| 10 | R _{Load Reg HE1, Total Reg HE1} = correlation between Load Reg HE1 and Total Reg HE1 |
| 11 | S _{Load Reg HE1} = standard deviation of Load Reg HE1 |
| 12 | S _{Total Reg HE1} = Standard deviation of Total Reg HE1 |

Table 2.8
Load Regulation Incremental Reserves Example

1
2 Reg *inc* _{Load} = Total Reg *inc* * Reg *inc* _{Load Max24} / Reg *inc* _{Total Max24}
3
4 Where Reg is Regulating Reserves
5 Reg *inc* _{Load Max24} = MAX(Reg *inc* _{Load HE1}, Reg *inc* _{Load HE2}, ..., Reg *inc* _{Load HE24})
6 Reg *inc* _{Total Max24} = Reg *inc* _{Load Max24} + Reg *inc* _{Wind Max24} + Reg *inc* _{Solar Max24} + Reg *inc* _{FCRPS Max24} + Reg *inc* _{Non-Fed Thermal Max24}

Table 2.9
Total Balancing Reserve Capacity Requirement (Values in MW)
for FY2022-2023 Balancing Reserve Capacity Quantity Forecast

| | | INSTALLED CAPACITY | | | | TOTAL | | | | | |
|--|-----------|--------------------|-------|---------------------|-------|-------|------|---------|------|-------|------|
| | | WIND | SOLAR | NON-FEDERAL THERMAL | FCRPS | REG | | NON-REG | | TOTAL | |
| | | | | | | INC | DEC | INC | DEC | INC | DEC |
| | A | B | C | D | E | F | G | J | K | L | M |
| 1 | Oct-21 | 2,930 | 89 | 1,548 | 3,384 | 310 | -332 | 397 | -529 | 707 | -861 |
| 2 | Nov-21 | 2,830 | 89 | 1,548 | 3,384 | 308 | -327 | 370 | -498 | 678 | -825 |
| 3 | Dec-21 | 2,830 | 89 | 1,548 | 3,384 | 308 | -327 | 370 | -498 | 678 | -825 |
| 4 | Jan-22 | 2,830 | 89 | 1,548 | 3,384 | 308 | -327 | 370 | -498 | 678 | -825 |
| 5 | Feb-22 | 2,830 | 89 | 1,548 | 3,384 | 308 | -327 | 370 | -498 | 678 | -825 |
| 6 | Mar-22 | 2,830 | 89 | 1,548 | 3,384 | 308 | -327 | 370 | -498 | 678 | -825 |
| 7 | Apr-22 | 2,830 | 89 | 1,548 | 3,384 | 308 | -327 | 370 | -498 | 678 | -825 |
| 8 | May-22 | 2,830 | 89 | 1,548 | 3,384 | 308 | -327 | 370 | -498 | 678 | -825 |
| 9 | Jun-22 | 2,830 | 89 | 1,548 | 3,384 | 308 | -327 | 370 | -498 | 678 | -825 |
| 10 | Jul-22 | 2,830 | 89 | 1,548 | 3,384 | 308 | -327 | 370 | -498 | 678 | -825 |
| 11 | Aug-22 | 2,830 | 89 | 1,548 | 3,384 | 308 | -327 | 370 | -498 | 678 | -825 |
| 12 | Sep-22 | 2,830 | 89 | 1,548 | 3,384 | 308 | -327 | 370 | -498 | 678 | -825 |
| 13 | Oct-22 | 2,830 | 109 | 1,548 | 3,384 | 309 | -327 | 370 | -498 | 680 | -825 |
| 14 | Nov-22 | 2,830 | 109 | 1,548 | 3,384 | 309 | -327 | 370 | -498 | 680 | -825 |
| 15 | Dec-22 | 2,830 | 109 | 1,548 | 3,384 | 309 | -327 | 370 | -498 | 680 | -825 |
| 16 | Jan-23 | 2,830 | 109 | 1,548 | 3,384 | 309 | -327 | 370 | -498 | 680 | -825 |
| 17 | Feb-23 | 2,830 | 109 | 1,548 | 3,384 | 309 | -327 | 370 | -498 | 680 | -825 |
| 18 | Mar-23 | 2,830 | 109 | 1,548 | 3,384 | 309 | -327 | 370 | -498 | 680 | -825 |
| 19 | Apr-23 | 2,830 | 109 | 1,548 | 3,384 | 309 | -327 | 370 | -498 | 680 | -825 |
| 20 | May-23 | 2,830 | 109 | 1,548 | 3,384 | 309 | -327 | 370 | -498 | 680 | -825 |
| 21 | Jun-23 | 2,830 | 109 | 1,548 | 3,384 | 309 | -327 | 370 | -498 | 680 | -825 |
| 22 | Jul-23 | 2,830 | 109 | 1,548 | 3,384 | 309 | -327 | 370 | -498 | 680 | -825 |
| 23 | Aug-23 | 2,830 | 109 | 1,548 | 3,384 | 309 | -327 | 370 | -498 | 680 | -825 |
| 24 | Sep-23 | 2,830 | 109 | 1,548 | 3,384 | 309 | -327 | 370 | -498 | 680 | -825 |
| 25 | BP-22 AVG | 2,834 | 99 | 1,548 | 3,384 | 309 | -327 | 371 | -499 | 680 | -827 |
| NOTES: * Load includes all Non-Federal Hydro ** Thermal includes new Thermal and Biomass as an allocated amount by nameplate capacity | | | | | | | | | | | |

Table 2.10
Load Balancing Reserve Capacity Requirement (Values in MW)
for FY2022-2023 Balancing Reserve Capacity Quantity Forecast

| | | INSTALLED CAPACITY | | | | LOAD* | | | | | | |
|---|------------------|--------------------|-------|---------------------|-------|-------|-----|---------|-----|-------|-----|------|
| | | WIND | SOLAR | NON-FEDERAL THERMAL | FCRPS | REG | | NON-REG | | TOTAL | | |
| | | | | | | INC | DEC | INC | DEC | INC | DEC | |
| | | A | B | C | D | E | F | G | J | K | L | M |
| 1 | Oct-21 | 2,930 | 89 | | 1,548 | 3,384 | 144 | -154 | 153 | -203 | 296 | -357 |
| 2 | Nov-21 | 2,830 | 89 | | 1,548 | 3,384 | 145 | -154 | 145 | -195 | 290 | -350 |
| 3 | Dec-21 | 2,830 | 89 | | 1,548 | 3,384 | 145 | -154 | 145 | -195 | 290 | -350 |
| 4 | Jan-22 | 2,830 | 89 | | 1,548 | 3,384 | 145 | -154 | 145 | -195 | 290 | -350 |
| 5 | Feb-22 | 2,830 | 89 | | 1,548 | 3,384 | 145 | -154 | 145 | -195 | 290 | -350 |
| 6 | Mar-22 | 2,830 | 89 | | 1,548 | 3,384 | 145 | -154 | 145 | -195 | 290 | -350 |
| 7 | Apr-22 | 2,830 | 89 | | 1,548 | 3,384 | 145 | -154 | 145 | -195 | 290 | -350 |
| 8 | May-22 | 2,830 | 89 | | 1,548 | 3,384 | 145 | -154 | 145 | -195 | 290 | -350 |
| 9 | Jun-22 | 2,830 | 89 | | 1,548 | 3,384 | 145 | -154 | 145 | -195 | 290 | -350 |
| 10 | Jul-22 | 2,830 | 89 | | 1,548 | 3,384 | 145 | -154 | 145 | -195 | 290 | -350 |
| 11 | Aug-22 | 2,830 | 89 | | 1,548 | 3,384 | 145 | -154 | 145 | -195 | 290 | -350 |
| 12 | Sep-22 | 2,830 | 89 | | 1,548 | 3,384 | 145 | -154 | 145 | -195 | 290 | -350 |
| 13 | Oct-22 | 2,830 | 109 | | 1,548 | 3,384 | 146 | -155 | 146 | -196 | 292 | -351 |
| 14 | Nov-22 | 2,830 | 109 | | 1,548 | 3,384 | 146 | -155 | 146 | -196 | 292 | -351 |
| 15 | Dec-22 | 2,830 | 109 | | 1,548 | 3,384 | 146 | -155 | 146 | -196 | 292 | -351 |
| 16 | Jan-23 | 2,830 | 109 | | 1,548 | 3,384 | 146 | -155 | 146 | -196 | 292 | -351 |
| 17 | Feb-23 | 2,830 | 109 | | 1,548 | 3,384 | 146 | -155 | 146 | -196 | 292 | -351 |
| 18 | Mar-23 | 2,830 | 109 | | 1,548 | 3,384 | 146 | -155 | 146 | -196 | 292 | -351 |
| 19 | Apr-23 | 2,830 | 109 | | 1,548 | 3,384 | 146 | -155 | 146 | -196 | 292 | -351 |
| 20 | May-23 | 2,830 | 109 | | 1,548 | 3,384 | 146 | -155 | 146 | -196 | 292 | -351 |
| 21 | Jun-23 | 2,830 | 109 | | 1,548 | 3,384 | 146 | -155 | 146 | -196 | 292 | -351 |
| 22 | Jul-23 | 2,830 | 109 | | 1,548 | 3,384 | 146 | -155 | 146 | -196 | 292 | -351 |
| 23 | Aug-23 | 2,830 | 109 | | 1,548 | 3,384 | 146 | -155 | 146 | -196 | 292 | -351 |
| 24 | Sep-23 | 2,830 | 109 | | 1,548 | 3,384 | 146 | -155 | 146 | -196 | 292 | -351 |
| 25 | BP-22 AVG | 2,834 | 99 | | 1,548 | 3,384 | 146 | -155 | 146 | -196 | 291 | -351 |
| NOTES: <ul style="list-style-type: none"> * Load includes all Non-Federal Hydro ** Thermal includes new Thermal and Biomass as an allocated amount by nameplate capacity | | | | | | | | | | | | |

Table 2.11
Wind Balancing Reserve Capacity Requirement (Values in MW)
for FY2022-2023 Balancing Reserve Capacity Quantity Forecast

| | | INSTALLED CAPACITY | | | | WIND | | | | | |
|----|-----------|--------------------|-------|---------------------|-------|------|------|---------|------|-------|------|
| | | WIND | SOLAR | NON-FEDERAL THERMAL | FCRPS | REG | | NON-REG | | TOTAL | |
| | | | | | | INC | DEC | INC | DEC | INC | DEC |
| | A | B | C | D | E | F | G | J | K | L | M |
| 1 | Oct-21 | 2,930 | 89 | 1,548 | 3,384 | 129 | -139 | 242 | -323 | 371 | -461 |
| 2 | Nov-21 | 2,830 | 89 | 1,548 | 3,384 | 125 | -133 | 223 | -300 | 348 | -433 |
| 3 | Dec-21 | 2,830 | 89 | 1,548 | 3,384 | 125 | -133 | 223 | -300 | 348 | -433 |
| 4 | Jan-22 | 2,830 | 89 | 1,548 | 3,384 | 125 | -133 | 223 | -300 | 348 | -433 |
| 5 | Feb-22 | 2,830 | 89 | 1,548 | 3,384 | 125 | -133 | 223 | -300 | 348 | -433 |
| 6 | Mar-22 | 2,830 | 89 | 1,548 | 3,384 | 125 | -133 | 223 | -300 | 348 | -433 |
| 7 | Apr-22 | 2,830 | 89 | 1,548 | 3,384 | 125 | -133 | 223 | -300 | 348 | -433 |
| 8 | May-22 | 2,830 | 89 | 1,548 | 3,384 | 125 | -133 | 223 | -300 | 348 | -433 |
| 9 | Jun-22 | 2,830 | 89 | 1,548 | 3,384 | 125 | -133 | 223 | -300 | 348 | -433 |
| 10 | Jul-22 | 2,830 | 89 | 1,548 | 3,384 | 125 | -133 | 223 | -300 | 348 | -433 |
| 11 | Aug-22 | 2,830 | 89 | 1,548 | 3,384 | 125 | -133 | 223 | -300 | 348 | -433 |
| 12 | Sep-22 | 2,830 | 89 | 1,548 | 3,384 | 125 | -133 | 223 | -300 | 348 | -433 |
| 13 | Oct-22 | 2,830 | 109 | 1,548 | 3,384 | 125 | -133 | 222 | -298 | 347 | -431 |
| 14 | Nov-22 | 2,830 | 109 | 1,548 | 3,384 | 125 | -133 | 222 | -298 | 347 | -431 |
| 15 | Dec-22 | 2,830 | 109 | 1,548 | 3,384 | 125 | -133 | 222 | -298 | 347 | -431 |
| 16 | Jan-23 | 2,830 | 109 | 1,548 | 3,384 | 125 | -133 | 222 | -298 | 347 | -431 |
| 17 | Feb-23 | 2,830 | 109 | 1,548 | 3,384 | 125 | -133 | 222 | -298 | 347 | -431 |
| 18 | Mar-23 | 2,830 | 109 | 1,548 | 3,384 | 125 | -133 | 222 | -298 | 347 | -431 |
| 19 | Apr-23 | 2,830 | 109 | 1,548 | 3,384 | 125 | -133 | 222 | -298 | 347 | -431 |
| 20 | May-23 | 2,830 | 109 | 1,548 | 3,384 | 125 | -133 | 222 | -298 | 347 | -431 |
| 21 | Jun-23 | 2,830 | 109 | 1,548 | 3,384 | 125 | -133 | 222 | -298 | 347 | -431 |
| 22 | Jul-23 | 2,830 | 109 | 1,548 | 3,384 | 125 | -133 | 222 | -298 | 347 | -431 |
| 23 | Aug-23 | 2,830 | 109 | 1,548 | 3,384 | 125 | -133 | 222 | -298 | 347 | -431 |
| 24 | Sep-23 | 2,830 | 109 | 1,548 | 3,384 | 125 | -133 | 222 | -298 | 347 | -431 |
| 25 | BP-22 AVG | 2,834 | 99 | 1,548 | 3,384 | 125 | -133 | 223 | -300 | 349 | -433 |

NOTES:

* Load includes all Non-Federal Hydro

** Thermal includes new Thermal and Biomass as an allocated amount by nameplate capacity

Table 2.12
Non-Federal Thermal Balancing Reserve Capacity Requirement (Values in MW)
for FY2022-2023 Balancing Reserve Capacity Quantity Forecast

| | | INSTALLED CAPACITY | | | | NON-FEDERAL THERMAL* | | | | | |
|----|-----------|--------------------|-------|------------------------|-------|----------------------|-----|---------|-----|-------|-----|
| | | WIND | SOLAR | NON-FEDERAL THERMAL | FCRPS | REG | | NON-REG | | TOTAL | |
| | | | | | | INC | DEC | INC | DEC | INC | DEC |
| A | B | C | D | E | F | G | J | K | L | M | |
| 1 | Oct-21 | 2,930 | 89 | 1,548 | 3,384 | 11 | -12 | 0 | 0 | 11 | -12 |
| 2 | Nov-21 | 2,830 | 89 | 1,548 | 3,384 | 11 | -12 | 0 | 0 | 11 | -12 |
| 3 | Dec-21 | 2,830 | 89 | 1,548 | 3,384 | 11 | -12 | 0 | 0 | 11 | -12 |
| 4 | Jan-22 | 2,830 | 89 | 1,548 | 3,384 | 11 | -12 | 0 | 0 | 11 | -12 |
| 5 | Feb-22 | 2,830 | 89 | 1,548 | 3,384 | 11 | -12 | 0 | 0 | 11 | -12 |
| 6 | Mar-22 | 2,830 | 89 | 1,548 | 3,384 | 11 | -12 | 0 | 0 | 11 | -12 |
| 7 | Apr-22 | 2,830 | 89 | 1,548 | 3,384 | 11 | -12 | 0 | 0 | 11 | -12 |
| 8 | May-22 | 2,830 | 89 | 1,548 | 3,384 | 11 | -12 | 0 | 0 | 11 | -12 |
| 9 | Jun-22 | 2,830 | 89 | 1,548 | 3,384 | 11 | -12 | 0 | 0 | 11 | -12 |
| 10 | Jul-22 | 2,830 | 89 | 1,548 | 3,384 | 11 | -12 | 0 | 0 | 11 | -12 |
| 11 | Aug-22 | 2,830 | 89 | 1,548 | 3,384 | 11 | -12 | 0 | 0 | 11 | -12 |
| 12 | Sep-22 | 2,830 | 89 | 1,548 | 3,384 | 11 | -12 | 0 | 0 | 11 | -12 |
| 13 | Oct-22 | 2,830 | 109 | 1,548 | 3,384 | 11 | -11 | 0 | 0 | 11 | -12 |
| 14 | Nov-22 | 2,830 | 109 | 1,548 | 3,384 | 11 | -11 | 0 | 0 | 11 | -12 |
| 15 | Dec-22 | 2,830 | 109 | 1,548 | 3,384 | 11 | -11 | 0 | 0 | 11 | -12 |
| 16 | Jan-23 | 2,830 | 109 | 1,548 | 3,384 | 11 | -11 | 0 | 0 | 11 | -12 |
| 17 | Feb-23 | 2,830 | 109 | 1,548 | 3,384 | 11 | -11 | 0 | 0 | 11 | -12 |
| 18 | Mar-23 | 2,830 | 109 | 1,548 | 3,384 | 11 | -11 | 0 | 0 | 11 | -12 |
| 19 | Apr-23 | 2,830 | 109 | 1,548 | 3,384 | 11 | -11 | 0 | 0 | 11 | -12 |
| 20 | May-23 | 2,830 | 109 | 1,548 | 3,384 | 11 | -11 | 0 | 0 | 11 | -12 |
| 21 | Jun-23 | 2,830 | 109 | 1,548 | 3,384 | 11 | -11 | 0 | 0 | 11 | -12 |
| 22 | Jul-23 | 2,830 | 109 | 1,548 | 3,384 | 11 | -11 | 0 | 0 | 11 | -12 |
| 23 | Aug-23 | 2,830 | 109 | 1,548 | 3,384 | 11 | -11 | 0 | 0 | 11 | -12 |
| 24 | Sep-23 | 2,830 | 109 | 1,548 | 3,384 | 11 | -11 | 0 | 0 | 11 | -12 |
| 25 | BP-22 AVG | 2,834 | 99 | 1,548 | 3,384 | 11 | -12 | 0 | 0 | 11 | -12 |

NOTES:

* Load includes all Non-Federal Hydro

** Thermal includes new Thermal and Biomass as an allocated amount by nameplate capacity

Table 2.13
Solar Balancing Reserve Capacity Requirement (Values in MW)
for FY2022-2023 Balancing Reserve Capacity Quantity Forecast

| | | INSTALLED CAPACITY | | | | SOLAR | | | | | |
|----|-----------|--------------------|-------|---------------------|-------|-------|-----|---------|-----|-------|-----|
| | | WIND | SOLAR | NON-FEDERAL THERMAL | FCRPS | REG | | NON-REG | | TOTAL | |
| | | | | | | INC | DEC | INC | DEC | INC | DEC |
| | A | B | C | D | E | F | G | J | K | L | M |
| 1 | Oct-21 | 2,930 | 89 | 1,548 | 3,384 | 3 | -4 | 2 | -3 | 6 | -7 |
| 2 | Nov-21 | 2,830 | 89 | 1,548 | 3,384 | 3 | -4 | 2 | -3 | 6 | -7 |
| 3 | Dec-21 | 2,830 | 89 | 1,548 | 3,384 | 3 | -4 | 2 | -3 | 6 | -7 |
| 4 | Jan-22 | 2,830 | 89 | 1,548 | 3,384 | 3 | -4 | 2 | -3 | 6 | -7 |
| 5 | Feb-22 | 2,830 | 89 | 1,548 | 3,384 | 3 | -4 | 2 | -3 | 6 | -7 |
| 6 | Mar-22 | 2,830 | 89 | 1,548 | 3,384 | 3 | -4 | 2 | -3 | 6 | -7 |
| 7 | Apr-22 | 2,830 | 89 | 1,548 | 3,384 | 3 | -4 | 2 | -3 | 6 | -7 |
| 8 | May-22 | 2,830 | 89 | 1,548 | 3,384 | 3 | -4 | 2 | -3 | 6 | -7 |
| 9 | Jun-22 | 2,830 | 89 | 1,548 | 3,384 | 3 | -4 | 2 | -3 | 6 | -7 |
| 10 | Jul-22 | 2,830 | 89 | 1,548 | 3,384 | 3 | -4 | 2 | -3 | 6 | -7 |
| 11 | Aug-22 | 2,830 | 89 | 1,548 | 3,384 | 3 | -4 | 2 | -3 | 6 | -7 |
| 12 | Sep-22 | 2,830 | 89 | 1,548 | 3,384 | 3 | -4 | 2 | -3 | 6 | -7 |
| 13 | Oct-22 | 2,830 | 109 | 1,548 | 3,384 | 4 | -4 | 3 | -4 | 6 | -8 |
| 14 | Nov-22 | 2,830 | 109 | 1,548 | 3,384 | 4 | -4 | 3 | -4 | 6 | -8 |
| 15 | Dec-22 | 2,830 | 109 | 1,548 | 3,384 | 4 | -4 | 3 | -4 | 6 | -8 |
| 16 | Jan-23 | 2,830 | 109 | 1,548 | 3,384 | 4 | -4 | 3 | -4 | 6 | -8 |
| 17 | Feb-23 | 2,830 | 109 | 1,548 | 3,384 | 4 | -4 | 3 | -4 | 6 | -8 |
| 18 | Mar-23 | 2,830 | 109 | 1,548 | 3,384 | 4 | -4 | 3 | -4 | 6 | -8 |
| 19 | Apr-23 | 2,830 | 109 | 1,548 | 3,384 | 4 | -4 | 3 | -4 | 6 | -8 |
| 20 | May-23 | 2,830 | 109 | 1,548 | 3,384 | 4 | -4 | 3 | -4 | 6 | -8 |
| 21 | Jun-23 | 2,830 | 109 | 1,548 | 3,384 | 4 | -4 | 3 | -4 | 6 | -8 |
| 22 | Jul-23 | 2,830 | 109 | 1,548 | 3,384 | 4 | -4 | 3 | -4 | 6 | -8 |
| 23 | Aug-23 | 2,830 | 109 | 1,548 | 3,384 | 4 | -4 | 3 | -4 | 6 | -8 |
| 24 | Sep-23 | 2,830 | 109 | 1,548 | 3,384 | 4 | -4 | 3 | -4 | 6 | -8 |
| 25 | BP-22 AVG | 2,834 | 99 | 1,548 | 3,384 | 4 | -4 | 2 | -3 | 6 | -7 |

NOTES:

* Load includes all Non-Federal Hydro

** Thermal includes new Thermal and Biomass as an allocated amount by nameplate capacity

Table 2.14
FCRPS Balancing Reserve Capacity Requirement (Values in MW)
for FY2022-2023 Balancing Reserve Capacity Quantity Forecast

| | | INSTALLED CAPACITY | | | | FCRPS | | | | | | |
|----|-----------|--------------------|-------|---------------------|-------|-------|-----|---------|-----|-------|-----|---|
| | | WIND | SOLAR | NON-FEDERAL THERMAL | FCRPS | REG | | NON-REG | | TOTAL | | |
| | | | | | | INC | DEC | INC | DEC | INC | DEC | |
| | | A | B | C | D | E | F | G | J | K | L | M |
| 1 | Oct-21 | 2,930 | 89 | 1,548 | 3,384 | 22 | -24 | 0 | 0 | 22 | -24 | |
| 2 | Nov-21 | 2,830 | 89 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 3 | Dec-21 | 2,830 | 89 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 4 | Jan-22 | 2,830 | 89 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 5 | Feb-22 | 2,830 | 89 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 6 | Mar-22 | 2,830 | 89 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 7 | Apr-22 | 2,830 | 89 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 8 | May-22 | 2,830 | 89 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 9 | Jun-22 | 2,830 | 89 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 10 | Jul-22 | 2,830 | 89 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 11 | Aug-22 | 2,830 | 89 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 12 | Sep-22 | 2,830 | 89 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 13 | Oct-22 | 2,830 | 109 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 14 | Nov-22 | 2,830 | 109 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 15 | Dec-22 | 2,830 | 109 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 16 | Jan-23 | 2,830 | 109 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 17 | Feb-23 | 2,830 | 109 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 18 | Mar-23 | 2,830 | 109 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 19 | Apr-23 | 2,830 | 109 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 20 | May-23 | 2,830 | 109 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 21 | Jun-23 | 2,830 | 109 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 22 | Jul-23 | 2,830 | 109 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 23 | Aug-23 | 2,830 | 109 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 24 | Sep-23 | 2,830 | 109 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |
| 25 | BP-22 AVG | 2,834 | 99 | 1,548 | 3,384 | 23 | -24 | 0 | 0 | 23 | -24 | |

NOTES:

* Load includes all Non-Federal Hydro

** Thermal includes new Thermal and Biomass as an allocated amount by nameplate capacity

Table 3.1
Balancing Area Net Load and Generation
MegaWatts

| | A | B | C | D | E | F | G |
|----|-----------------------------------|---------------|---------------|---------------|---------------|---------------|---------------|
| | BPA BALANCING AREA NET LOAD | | | | | | |
| | Month | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 |
| 1 | OCT | 5,747 | 5,745 | 6,062 | 5,589 | 5,584 | 5,669 |
| 2 | NOV | 6,320 | 5,766 | 6,635 | 6,336 | 6,156 | 6,256 |
| 3 | DEC | 7,392 | 6,580 | 7,028 | 6,881 | 7,068 | 7,177 |
| 4 | JAN | 6,866 | 6,261 | 7,061 | 6,771 | 6,944 | 7,051 |
| 5 | FEB | 7,171 | 7,677 | 6,964 | 7,203 | 6,869 | 6,975 |
| 6 | MAR | 6,642 | 6,825 | 6,644 | 6,359 | 6,394 | 6,493 |
| 7 | APR | 6,145 | 6,123 | 6,048 | 5,964 | 5,997 | 6,090 |
| 8 | MAY | 5,883 | 5,824 | 5,852 | 5,793 | 5,825 | 5,915 |
| 9 | JUN | 6,115 | 6,099 | 5,972 | 6,075 | 6,108 | 6,203 |
| 10 | JUL | 6,389 | 6,112 | 6,276 | 6,204 | 6,238 | 6,335 |
| 11 | AUG | 6,090 | 6,122 | 6,087 | 6,031 | 6,065 | 6,159 |
| 12 | SEP | 5,675 | 5,749 | 5,381 | 5,593 | 5,624 | 5,710 |
| 13 | AVG | 6,370 | 6,240 | 6,334 | 6,233 | 6,239 | 6,336 |
| 14 | BPA BALANCING AREA NET GENERATION | | | | | | |
| 15 | Month | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 |
| 16 | OCT | 10,273 | 7,929 | 7,803 | 8,718 | 9,881 | 9,831 |
| 17 | NOV | 11,574 | 9,929 | 9,590 | 10,476 | 11,715 | 11,518 |
| 18 | DEC | 13,453 | 10,073 | 9,652 | 10,936 | 11,929 | 11,979 |
| 19 | JAN | 14,735 | 10,753 | 11,313 | 12,432 | 13,405 | 12,604 |
| 20 | FEB | 15,993 | 10,117 | 12,980 | 12,333 | 13,050 | 14,169 |
| 21 | MAR | 13,899 | 10,376 | 10,076 | 11,305 | 13,561 | 11,913 |
| 22 | APR | 13,354 | 11,515 | 9,042 | 12,034 | 14,830 | 14,648 |
| 23 | MAY | 14,759 | 12,042 | 12,824 | 12,108 | 12,046 | 12,517 |
| 24 | JUN | 14,537 | 11,166 | 13,550 | 14,354 | 14,588 | 15,090 |
| 25 | JUL | 12,082 | 9,842 | 12,595 | 12,276 | 13,668 | 14,462 |
| 26 | AUG | 16,485 | 9,277 | 10,935 | 11,105 | 14,480 | 14,427 |
| 27 | SEP | 14,933 | 8,236 | 8,991 | 10,170 | 10,600 | 10,932 |
| 28 | AVG | 13,840 | 10,105 | 10,779 | 11,521 | 12,813 | 12,841 |

Table 3.2
Forecast Operating Reserve Obligation
MegaWatts

| A | B | C | D |
|--|--------------|--------------|--------------|
| Total Balancing Area Obligation | | | |
| 1 Month | 2022 | 2023 | AVG |
| 2 Oct | 464.0 | 465.0 | 464.5 |
| 3 Nov | 536.0 | 533.1 | 534.5 |
| 4 Dec | 569.8 | 574.8 | 572.3 |
| 5 Jan | 610.6 | 589.8 | 600.2 |
| 6 Feb | 597.6 | 634.2 | 615.9 |
| 7 Mar | 598.7 | 552.3 | 575.5 |
| 8 Apr | 624.9 | 622.0 | 623.5 |
| 9 May | 536.0 | 553.0 | 544.5 |
| 10 Jun | 620.9 | 638.8 | 629.8 |
| 11 Jul | 597.1 | 624.0 | 610.5 |
| 12 Aug | 616.4 | 617.5 | 617.0 |
| 13 Sep | 486.9 | 499.2 | 493.0 |
| 14 AVG | 571.6 | 575.3 | 573.4 |
| 15 | | | |
| 16 | | | |
| Self- and Third Party Supply | | | |
| 17 Month | FY22 | FY23 | AVG |
| 18 Oct | 88.6 | 88.6 | 88.6 |
| 19 Nov | 112.6 | 112.6 | 112.6 |
| 20 Dec | 119.4 | 119.4 | 119.4 |
| 21 Jan | 125.0 | 125.0 | 125.0 |
| 22 Feb | 124.7 | 124.7 | 124.7 |
| 23 Mar | 110.8 | 110.8 | 110.8 |
| 24 Apr | 86.7 | 86.7 | 86.7 |
| 25 May | 85.4 | 85.4 | 85.4 |
| 26 Jun | 83.8 | 83.8 | 83.8 |
| 27 Jul | 88.9 | 88.9 | 88.9 |
| 28 Aug | 87.6 | 87.6 | 87.6 |
| 29 Sep | 86.6 | 86.6 | 86.6 |
| 30 AVG | 100.0 | 100.0 | 100.0 |
| 31 | | | |
| 32 | | | |
| BPA Obligation | | | |
| 33 Month | 2022 | 2023 | AVG |
| 34 Oct | 375.4 | 376.4 | 375.9 |
| 35 Nov | 423.4 | 420.5 | 421.9 |
| 36 Dec | 450.4 | 455.5 | 452.9 |
| 37 Jan | 485.6 | 464.8 | 475.2 |
| 38 Feb | 472.9 | 509.5 | 491.2 |
| 39 Mar | 487.9 | 441.5 | 464.7 |
| 40 Apr | 538.3 | 535.4 | 536.8 |
| 41 May | 450.6 | 467.6 | 459.1 |
| 42 Jun | 537.1 | 555.0 | 546.1 |
| 43 Jul | 508.2 | 535.1 | 521.6 |
| 44 Aug | 528.9 | 529.9 | 529.4 |
| 45 Sep | 400.3 | 412.5 | 406.4 |
| 46 AVG | 471.6 | 475.3 | 473.4 |
| 47 | | | |

Table 4.1
1-Hour Capacity of Federal System Resources for FY 2022 and FY 2023 Adjusted for Transmission Losses (without reserve obligations)
1937 Water Conditions

| | | Annual Average | Oct | Nov | Dec | Jan | Feb | Mar | 1-Apr | 16-Apr | May | Jun | Jul | 1-Aug | 16-Aug | Sep |
|----|--|-----------------|---------|----------|----------|----------|----------|----------|----------|---------|----------|----------|----------|----------|----------|----------|
| | | B | C | D | E | F | G | H | I | J | K | L | M | N | O | P |
| 1 | FY 2022 Federal Resources | | | | | | | | | | | | | | | |
| 2 | Regulated Hydro | 11,992.7 | 9,823.6 | 12,272.2 | 13,258.4 | 11,248.1 | 10,803.1 | 12,703.5 | 10,760.1 | 8,783.3 | 13,725.9 | 14,835.0 | 12,476.3 | 12,167.3 | 11,866.2 | 10,860.4 |
| 3 | Independent Hydro | 487.2 | 471.9 | 416.9 | 311.0 | 198.0 | 225.1 | 385.4 | 613.0 | 628.7 | 814.5 | 839.7 | 605.3 | 463.2 | 463.2 | 482.8 |
| 4 | Small Hydro | 4.2 | 4.1 | 4.5 | 4.6 | 4.6 | 4.6 | 4.6 | 4.6 | 4.6 | 4.6 | 4.1 | 3.2 | 3.5 | 3.5 | 3.0 |
| 5 | Large Thermal (Columbia Generation Station) | 1,168.5 | 1,181.0 | 1,179.0 | 1,180.0 | 1,169.0 | 1,169.0 | 1,169.0 | 1,160.0 | 1,160.0 | 1,151.0 | 1,154.0 | 1,168.0 | 1,163.0 | 1,163.0 | 1,179.0 |
| 6 | Renewable Resources | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 7 | Augmentation Purchases | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 8 | Augmentation Purchases (to serve Tier 2 Load) | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 9 | FY 2023 Federal Resources | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 10 | Regulated Hydro | 11,915.0 | 9,760.0 | 12,507.7 | 13,188.3 | 11,369.2 | 10,914.2 | 10,856.6 | 10,853.4 | 8,934.7 | 14,107.2 | 14,933.4 | 12,501.5 | 12,151.8 | 11,897.9 | 10,846.8 |
| 11 | Independent Hydro | 487.2 | 471.9 | 416.9 | 311.0 | 198.0 | 225.1 | 385.4 | 613.0 | 628.7 | 814.5 | 839.7 | 605.3 | 463.2 | 463.2 | 482.8 |
| 12 | Small Hydro | 4.2 | 4.1 | 4.5 | 4.6 | 4.6 | 4.6 | 4.6 | 4.6 | 4.6 | 4.6 | 4.1 | 3.2 | 3.5 | 3.5 | 3.0 |
| 13 | Large Thermal (Columbia Generation Station) | 975.9 | 1,181.0 | 1,179.0 | 1,180.0 | 1,169.0 | 1,169.0 | 1,169.0 | 1,160.0 | 1,160.0 | - | - | 1,168.0 | 1,163.0 | 1,163.0 | 1,179.0 |
| 14 | Renewable Resources | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 15 | Augmentation Purchases | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 16 | Augmentation Purchases (to serve Tier 2 Load) | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 17 | Rate Period Average After Losses | - | | | | | | | | | | | | | | |
| 18 | Regulated Hydro | 11,581.0 | | | | | | | | | | | | | | |
| 19 | Independent Hydro | 471.9 | | | | | | | | | | | | | | |
| 20 | Small Hydro | 4.0 | | | | | | | | | | | | | | |
| 21 | Large Thermal (Columbia Generation Station) | 1,038.9 | | | | | | | | | | | | | | |
| 22 | Renewable Resources | - | | | | | | | | | | | | | | |
| 23 | Augmentation Purchases | - | | | | | | | | | | | | | | |
| 24 | Augmentation Purchases (to serve Tier 2 Load) | - | | | | | | | | | | | | | | |
| 25 | 1-Hour Capacity Adjusted for Transmission Losses | 13,095.9 | | | | | | | | | | | | | | |

| | Oct | Nov | Dec | Jan | Feb | Mar | 1-Apr | 16-Apr | May | Jun | Jul | 1-Aug | 16-Aug | Sep |
|------|-----|-----|-----|-----|-----|-----|-------|--------|-----|-----|-----|-------|--------|-----|
| 2022 | 31 | 30 | 31 | 31 | 28 | 31 | 15 | 15 | 31 | 30 | 31 | 15 | 16 | 30 |
| 2023 | 31 | 30 | 31 | 31 | 28 | 31 | 15 | 15 | 31 | 30 | 31 | 15 | 16 | 30 |

Table 4.2
Capacity Costs
(\$ in thousands)

| | A | B | C | Capacity Classification (%) | D |
|----|---|--------------------|--------------------|-----------------------------|---|
| | | FY 2022 | FY 2023 | | Annual Average for FY 2022-FY 2023 Classified to Capacity |
| 1 | Capital Related Costs | | | | |
| 2 | Depreciation | \$ 140,949 | \$ 144,155 | 100% | \$ 142,552 |
| 3 | Amortization | \$ 278,822 | \$ 284,344 | 100% | \$ 281,583 |
| 4 | Interest Expense | \$ 252,948 | \$ 239,995 | 100% | \$ 246,471 |
| 5 | Minimum Required Net Revenues | \$ 67,831 | \$ 104,443 | 100% | \$ 86,137 |
| 6 | Decommissioning Costs | \$ 25,839 | \$ 27,023 | 100% | \$ 26,430.95 |
| 7 | Subtotal | \$ 766,388 | \$ 799,960 | | \$ 783,174 |
| 8 | | | | | |
| 9 | Fish & Wildlife Costs | | | | |
| 10 | Fish & Wildlife (Other than Planning Council) | \$ 280,508 | \$ 276,196 | 100% | \$ 278,352 |
| 11 | Fish & Wildlife - Planning Council | \$ 11,942 | \$ 12,431 | 50% | \$ 6,093 |
| 12 | Subtotal | \$ 280,508 | \$ 276,196 | | \$ 284,445 |
| 13 | | | | | |
| 14 | Power Purchase Costs | | | | |
| 15 | Clearwater Hatchery Generation | \$ 1,368 | \$ 1,410 | 60% | \$ 840 |
| 16 | Non-Tier 2 Augmentation Power Purchases | \$ - | \$ - | 50% | \$ - |
| 17 | Tier 2 Augmentation Power Purchases | \$ - | \$ - | 50% | \$ - |
| 18 | Subtotal | \$ 1,368 | \$ 1,410 | | \$ 840 |
| 19 | | | | | |
| 20 | Cost Adjustments | | | | |
| 21 | 4h10C | \$ (94,171) | \$ (94,216) | 69% | \$ (64,748.42) |
| 22 | Synchronous Condensing | \$ (923) | \$ (923) | 20% | \$ (185) |
| 23 | Subtotal | \$ (95,094) | \$ (95,138) | | \$ (64,933) |
| 24 | Total Allocated Costs | | | | \$ 1,003,526 |

Table 4.3
Embedded Cost Calculation
(*\$* in Thousands)

| | A | B |
|----|--|--|
| | | Annual Average of FY2022-FY2023 |
| 1 | Assumptions for Calculation: | |
| 2 | 1Hr Capacity adjusted for Transmission Losses (MW) | 13,096 |
| 3 | Regulation Reserve (MW) | 309 |
| 4 | Non-regulation Reserve (MW) | 371 |
| 5 | Operating Reserve (MW) | 473 |
| 6 | | |
| 7 | Forecast of Total Capacity of Federal System Resources: | |
| 8 | 1Hr Capacity adjusted for Transmission Losses (Line 2) | 13,096 |
| 9 | Total PS Reserve Obligation (Line 3+4+5) | 1,153 |
| 10 | Total Capacity of Federal System Resources (Line 8+9) | 14,249 |
| 11 | | |
| 12 | Revenue Requirement: | |
| 13 | Capacity Costs | \$ 1,003,526 |
| 14 | Hydro Projects Capacity System Uses (Line 10) | 14,249 |
| 15 | Total kW/month/year Hydro Project Capacity System Uses (Line 14 * 12 months * 1000 kW/MW) | 170,991,635 |
| 16 | Unit Cost Allocation of Capacity System Uses \$/kW/month (Line 13 / Line 15) | \$ 5.87 |

Table 4.4
Super Peak Market Prices for FY 2022 by Month and Water Year
(\$/MWh)

| | A | B | C | D | E | F | G | H | I | J | K | L | M |
|-----------|------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | Water Year | Oct-21 | Nov-21 | Dec-21 | Jan-22 | Feb-22 | Mar-22 | Apr-22 | May-22 | Jun-22 | Jul-22 | Aug-22 | Sep-22 |
| 1 | 1929 | 50.40 | 51.34 | 65.59 | 61.00 | 66.85 | 63.78 | 60.51 | 58.85 | 52.72 | 86.88 | 78.44 | 52.85 |
| 2 | 1930 | 62.40 | 58.75 | 65.67 | 62.33 | 70.19 | 63.39 | 64.38 | 59.26 | 52.91 | 71.60 | 73.52 | 53.13 |
| 3 | 1931 | 64.44 | 53.24 | 64.39 | 62.22 | 66.50 | 60.01 | 62.47 | 57.64 | 49.51 | 74.31 | 69.75 | 52.03 |
| 4 | 1932 | 58.29 | 54.28 | 66.96 | 63.99 | 110.56 | 69.26 | 57.94 | 47.23 | 39.68 | 87.61 | 70.96 | 54.90 |
| 5 | 1933 | 57.34 | 56.32 | 60.37 | 65.18 | 72.94 | 60.69 | 62.43 | 54.38 | 18.86 | 60.52 | 63.35 | 51.63 |
| 6 | 1934 | 46.39 | 54.32 | 62.00 | 57.88 | 71.17 | 63.20 | 41.76 | 49.82 | 54.60 | 100.92 | 79.93 | 56.97 |
| 7 | 1935 | 59.60 | 62.30 | 62.03 | 61.14 | 71.44 | 60.14 | 62.71 | 57.09 | 54.28 | 69.50 | 63.95 | 52.59 |
| 8 | 1936 | 55.05 | 56.16 | 62.67 | 64.28 | 75.43 | 67.83 | 61.03 | 40.54 | 49.36 | 76.61 | 73.78 | 56.06 |
| 9 | 1937 | 58.34 | 57.52 | 67.01 | 68.77 | 88.30 | 64.53 | 64.34 | 61.30 | 56.90 | 76.52 | 75.27 | 52.16 |
| 10 | 1938 | 51.16 | 52.09 | 59.95 | 63.52 | 65.36 | 63.36 | 54.48 | 47.18 | 46.27 | 74.19 | 82.80 | 60.22 |
| 11 | 1939 | 56.01 | 58.03 | 62.84 | 60.09 | 66.55 | 63.19 | 59.48 | 53.29 | 54.61 | 71.25 | 68.78 | 53.26 |
| 12 | 1940 | 56.56 | 51.55 | 60.90 | 58.95 | 69.45 | 66.07 | 62.75 | 59.15 | 53.82 | 87.36 | 83.47 | 55.21 |
| 13 | 1941 | 55.74 | 53.81 | 60.77 | 61.98 | 68.84 | 60.89 | 62.26 | 59.33 | 50.94 | 78.53 | 72.93 | 53.22 |
| 14 | 1942 | 54.16 | 53.36 | 59.75 | 56.71 | 70.90 | 60.61 | 58.73 | 57.23 | 44.88 | 68.47 | 67.75 | 48.97 |
| 15 | 1943 | 57.51 | 55.73 | 60.00 | 62.99 | 73.87 | 65.11 | 41.58 | 53.54 | 35.21 | 61.88 | 74.56 | 57.88 |
| 16 | 1944 | 57.39 | 55.73 | 62.10 | 63.25 | 66.93 | 62.01 | 69.37 | 59.55 | 50.39 | 77.14 | 76.11 | 54.12 |
| 17 | 1945 | 54.36 | 53.64 | 60.35 | 62.91 | 72.21 | 61.91 | 66.02 | 55.58 | 46.35 | 86.13 | 73.20 | 51.01 |
| 18 | 1946 | 57.70 | 53.70 | 60.47 | 62.28 | 67.65 | 61.91 | 46.75 | 43.48 | 49.64 | 69.19 | 60.15 | 51.19 |
| 19 | 1947 | 57.78 | 52.78 | 65.84 | 60.82 | 69.61 | 63.01 | 58.77 | 47.78 | 46.68 | 71.97 | 71.31 | 54.82 |
| 20 | 1948 | 39.24 | 54.25 | 58.64 | 69.22 | 77.66 | 62.45 | 60.77 | 24.87 | 17.85 | 80.96 | 59.80 | 50.20 |
| 21 | 1949 | 51.21 | 52.26 | 62.99 | 56.53 | 65.74 | 64.39 | 53.04 | 34.51 | 50.76 | 85.70 | 70.78 | 52.39 |
| 22 | 1950 | 59.06 | 52.83 | 57.92 | 66.23 | 73.61 | 61.79 | 52.51 | 55.58 | 20.89 | 40.29 | 67.05 | 55.42 |
| 23 | 1951 | 45.93 | 53.96 | 68.33 | 57.31 | 62.46 | 61.79 | 49.59 | 46.92 | 50.33 | 62.40 | 68.00 | 55.07 |
| 24 | 1952 | 49.07 | 54.88 | 57.47 | 67.10 | 72.70 | 62.47 | 46.32 | 34.13 | 46.64 | 68.53 | 66.94 | 54.40 |
| 25 | 1953 | 63.88 | 54.62 | 65.76 | 61.43 | 72.60 | 64.40 | 71.71 | 52.93 | 17.69 | 65.91 | 68.26 | 50.81 |
| 26 | 1954 | 53.33 | 52.81 | 60.06 | 67.45 | 72.75 | 60.46 | 59.41 | 44.41 | 35.51 | 48.59 | 61.22 | 51.01 |
| 27 | 1955 | 50.60 | 52.33 | 55.31 | 59.32 | 67.09 | 64.47 | 61.94 | 55.33 | 28.07 | 46.62 | 64.01 | 54.00 |
| 28 | 1956 | 50.07 | 56.40 | 63.24 | 57.98 | 73.19 | 66.15 | 41.50 | 35.82 | 18.52 | 68.48 | 62.98 | 49.69 |
| 29 | 1957 | 52.75 | 54.76 | 56.89 | 61.86 | 67.45 | 63.36 | 52.40 | 25.13 | 21.44 | 82.15 | 64.86 | 53.05 |
| 30 | 1958 | 58.29 | 54.41 | 61.08 | 65.52 | 76.36 | 63.17 | 60.18 | 35.51 | 39.81 | 87.03 | 68.77 | 51.19 |
| 31 | 1959 | 50.94 | 53.42 | 60.78 | 67.22 | 74.82 | 64.97 | 62.27 | 58.53 | 31.90 | 61.15 | 62.75 | 47.28 |
| 32 | 1960 | 36.58 | 55.77 | 62.54 | 62.87 | 72.81 | 61.57 | 52.23 | 61.22 | 44.97 | 71.92 | 68.10 | 57.54 |
| 33 | 1961 | 53.22 | 54.12 | 60.71 | 61.23 | 72.63 | 63.30 | 61.46 | 51.04 | 34.99 | 88.27 | 68.25 | 52.68 |
| 34 | 1962 | 59.21 | 55.13 | 60.20 | 61.33 | 74.07 | 64.40 | 54.05 | 54.35 | 44.61 | 78.27 | 68.14 | 54.24 |
| 35 | 1963 | 52.27 | 54.31 | 56.05 | 59.31 | 75.88 | 64.49 | 62.58 | 54.03 | 44.82 | 68.98 | 72.59 | 50.26 |
| 36 | 1964 | 55.05 | 53.33 | 59.49 | 60.36 | 70.99 | 62.60 | 64.74 | 52.63 | 16.16 | 54.52 | 64.63 | 49.30 |
| 37 | 1965 | 45.53 | 50.39 | 60.76 | 61.19 | 61.10 | 59.23 | 56.87 | 41.22 | 44.29 | 71.67 | 59.27 | 48.00 |
| 38 | 1966 | 53.24 | 58.08 | 61.69 | 60.99 | 72.00 | 63.79 | 61.08 | 58.57 | 51.93 | 67.89 | 69.44 | 53.16 |
| 39 | 1967 | 52.83 | 53.81 | 55.04 | 66.63 | 72.82 | 62.30 | 57.57 | 53.66 | 19.49 | 64.03 | 63.92 | 48.63 |
| 40 | 1968 | 51.84 | 52.56 | 59.85 | 65.32 | 67.92 | 64.55 | 92.19 | 55.82 | 41.79 | 70.77 | 65.33 | 47.72 |
| 41 | 1969 | 44.94 | 50.94 | 58.21 | 62.89 | 75.09 | 64.00 | 40.09 | 40.21 | 46.55 | 67.43 | 67.30 | 52.46 |
| 42 | 1970 | 55.84 | 55.11 | 63.91 | 63.83 | 74.02 | 59.89 | 69.76 | 52.05 | 29.96 | 87.98 | 72.60 | 51.55 |
| 43 | 1971 | 52.69 | 53.29 | 56.62 | 61.32 | 59.90 | 61.20 | 53.11 | 32.81 | 11.43 | 64.65 | 60.93 | 48.48 |
| 44 | 1972 | 49.44 | 54.65 | 57.56 | 59.92 | 69.66 | 31.07 | 48.17 | 39.84 | 13.77 | 63.31 | 59.38 | 50.31 |
| 45 | 1973 | 47.33 | 53.42 | 56.35 | 60.86 | 71.85 | 66.01 | 71.92 | 62.00 | 52.22 | 81.10 | 83.36 | 56.24 |
| 46 | 1974 | 57.12 | 54.90 | 57.19 | 49.61 | 59.41 | 50.70 | 41.14 | 44.74 | 13.73 | 46.38 | 59.72 | 52.25 |
| 47 | 1975 | 58.49 | 55.44 | 58.76 | 58.84 | 73.01 | 59.54 | 60.65 | 47.49 | 21.38 | 61.09 | 71.40 | 49.72 |
| 48 | 1976 | 43.53 | 55.81 | 63.06 | 61.52 | 70.89 | 63.03 | 51.78 | 37.35 | 41.11 | 60.23 | 51.59 | 49.05 |
| 49 | 1977 | 55.32 | 57.63 | 63.55 | 63.50 | 65.73 | 66.28 | 74.71 | 60.71 | 53.67 | 85.58 | 76.67 | 58.01 |
| 50 | 1978 | 57.26 | 57.69 | 58.61 | 64.64 | 70.25 | 65.50 | 56.32 | 51.97 | 53.58 | 74.88 | 75.49 | 46.93 |
| 51 | 1979 | 52.38 | 55.34 | 62.49 | 61.44 | 67.89 | 67.46 | 61.82 | 46.65 | 53.60 | 81.94 | 74.75 | 53.33 |
| 52 | 1980 | 55.05 | 55.61 | 66.43 | 59.64 | 67.66 | 65.85 | 61.74 | 37.26 | 42.19 | 80.05 | 73.00 | 53.95 |
| 53 | 1981 | 58.58 | 56.52 | 63.39 | 66.10 | 76.21 | 63.43 | 69.93 | 56.21 | 32.92 | 68.68 | 64.93 | 52.61 |
| 54 | 1982 | 51.26 | 51.56 | 55.72 | 61.99 | 68.43 | 48.98 | 55.56 | 43.41 | 24.57 | 54.61 | 62.67 | 48.86 |
| 55 | 1983 | 47.06 | 56.56 | 57.80 | 65.53 | 73.52 | 52.52 | 59.41 | 53.78 | 46.51 | 61.27 | 63.41 | 52.93 |
| 56 | 1984 | 52.96 | 59.53 | 57.54 | 63.66 | 72.02 | 65.09 | 61.34 | 55.85 | 30.10 | 72.52 | 69.41 | 53.26 |
| 57 | 1985 | 49.45 | 54.18 | 59.63 | 63.73 | 69.36 | 62.95 | 63.53 | 56.46 | 47.11 | 84.98 | 81.97 | 54.77 |
| 58 | 1986 | 46.93 | 51.47 | 58.34 | 67.02 | 72.54 | 46.92 | 53.76 | 58.40 | 45.65 | 80.91 | 74.26 | 54.90 |
| 59 | 1987 | 59.28 | 56.13 | 58.94 | 62.42 | 68.49 | 66.04 | 61.70 | 55.73 | 55.97 | 100.40 | 75.15 | 55.42 |
| 60 | 1988 | 57.21 | 55.45 | 63.84 | 67.29 | 74.27 | 65.00 | 62.14 | 62.56 | 53.40 | 70.33 | 75.32 | 54.56 |
| 61 | 1989 | 65.47 | 50.14 | 58.12 | 58.64 | 83.96 | 62.75 | 56.47 | 56.82 | 52.44 | 74.41 | 74.10 | 53.09 |
| 62 | 1990 | 56.26 | 56.70 | 59.91 | 64.57 | 72.88 | 61.85 | 57.54 | 61.01 | 45.80 | 64.00 | 65.47 | 52.75 |
| 63 | 1991 | 61.15 | 55.70 | 58.39 | 63.81 | 71.35 | 58.40 | 58.26 | 54.68 | 47.44 | 60.02 | 62.47 | 54.07 |
| 64 | 1992 | 60.23 | 53.16 | 67.31 | 62.00 | 69.25 | 67.73 | 63.84 | 57.49 | 53.39 | 90.65 | 79.03 | 56.81 |
| 65 | 1993 | 70.90 | 52.45 | 63.86 | 62.29 | 83.53 | 59.94 | 59.62 | 41.52 | 52.30 | 71.44 | 67.60 | 51.09 |
| 66 | 1994 | 61.86 | 54.27 | 62.81 | 63.40 | 68.65 | 63.58 | 59.43 | 53.29 | 51.31 | 77.89 | 78.22 | 54.10 |
| 67 | 1995 | 59.44 | 54.86 | 60.65 | 61.13 | 66.52 | 63.47 | 69.36 | 53.43 | 38.66 | 73.05 | 74.45 | 50.53 |
| 68 | 1996 | 47.55 | 50.35 | 53.32 | 50.30 | 58.52 | 44.31 | 47.73 | 46.85 | 37.23 | 68.31 | 69.76 | 54.50 |
| 69 | 1997 | 58.44 | 58.11 | 56.49 | 53.43 | 62.29 | 46.28 | 31.89 | 25.17 | 17.00 | 58.29 | 63.42 | 53.10 |
| 70 | 1998 | 38.55 | 50.61 | 61.23 | 59.66 | 70.09 | 65.09 | 64.17 | 39.67 | 38.57 | 69.12 | 64.09 | 52.17 |
| 71 | 1999 | 57.12 | 54.40 | 57.00 | 62.26 | 74.90 | 52.14 | 54.29 | 53.33 | 26.10 | 58.31 | 54.75 | 54.67 |
| 72 | 2000 | 63.10 | 59.58 | 57.99 | 60.86 | 70.77 | 62.18 | 50.80 | 57.58 | 55.13 | 69.65 | 72.91 | 56.28 |
| 73 | 2001 | 58.28 | 57.45 | 63.36 | 64.75 | 68.21 | 64.67 | 71.17 | 58.80 | 51.72 | 90.02 | 81.25 | 58.17 |
| 74 | 2002 | 59.26 | 57.48 | 59.51 | 60.37 | 69.03 | 62.40 | 59.06 | 54.30 | 38.59 | 63.88 | 76.52 | 58.78 |
| 75 | 2003 | 62.91 | 55.8 | | | | | | | | | | |

Table 4.5
Super Peak Market Prices for FY 2023 by Month and Water Year
(\$/MWh)

| | A | B | C | D | E | F | G | H | I | J | K | L | M |
|----|------------|--------|--------|--------|---------|--------|--------|--------|--------|--------|--------|--------|--------|
| | Water Year | Oct-22 | Nov-22 | Dec-22 | Jan-23 | Feb-23 | Mar-23 | Apr-23 | May-23 | Jun-23 | Jul-23 | Aug-23 | Sep-23 |
| 1 | 1929 | 53.53 | 57.61 | 62.30 | 60.08 | 69.25 | 68.28 | 73.92 | 71.63 | 46.79 | 83.34 | 66.82 | 52.12 |
| 2 | 1930 | 66.90 | 62.42 | 67.12 | 61.36 | 70.59 | 67.87 | 75.36 | 66.65 | 51.63 | 70.49 | 69.00 | 51.29 |
| 3 | 1931 | 67.42 | 60.58 | 65.21 | 61.32 | 71.90 | 66.54 | 75.50 | 68.74 | 54.74 | 70.97 | 69.22 | 50.74 |
| 4 | 1932 | 66.20 | 61.22 | 63.89 | 59.74 | 80.67 | 67.19 | 53.58 | 56.60 | 45.29 | 77.33 | 60.10 | 48.46 |
| 5 | 1933 | 62.56 | 60.30 | 57.45 | 65.07 | 73.04 | 67.39 | 71.56 | 59.51 | 22.12 | 58.75 | 58.11 | 49.09 |
| 6 | 1934 | 48.22 | 56.66 | 60.12 | 54.53 | 69.09 | 66.54 | 47.42 | 59.37 | 61.13 | 92.43 | 68.59 | 51.12 |
| 7 | 1935 | 66.35 | 62.99 | 58.65 | 60.75 | 72.10 | 66.41 | 69.68 | 62.60 | 50.64 | 61.80 | 59.30 | 47.85 |
| 8 | 1936 | 62.43 | 62.29 | 68.69 | 64.39 | 79.12 | 69.98 | 71.65 | 52.31 | 55.81 | 81.89 | 67.98 | 53.90 |
| 9 | 1937 | 66.96 | 65.85 | 63.69 | 69.16 | 80.19 | 68.50 | 75.06 | 68.10 | 50.66 | 74.97 | 70.56 | 51.96 |
| 10 | 1938 | 56.31 | 56.98 | 56.36 | 60.82 | 68.08 | 66.66 | 56.30 | 57.05 | 54.10 | 69.96 | 69.18 | 50.53 |
| 11 | 1939 | 70.06 | 64.37 | 65.60 | 60.42 | 69.81 | 66.54 | 69.06 | 59.09 | 52.10 | 68.97 | 73.23 | 54.06 |
| 12 | 1940 | 61.31 | 60.27 | 62.50 | 60.92 | 70.48 | 65.76 | 67.02 | 64.22 | 57.67 | 76.96 | 74.45 | 52.21 |
| 13 | 1941 | 59.86 | 59.54 | 60.39 | 59.60 | 70.66 | 66.00 | 73.01 | 67.16 | 52.32 | 72.80 | 64.28 | 49.60 |
| 14 | 1942 | 57.19 | 58.30 | 61.82 | 59.34 | 71.43 | 68.47 | 70.23 | 69.35 | 47.05 | 62.71 | 64.73 | 48.98 |
| 15 | 1943 | 61.06 | 56.84 | 56.63 | 63.23 | 72.21 | 64.26 | 34.08 | 59.81 | 39.38 | 57.97 | 59.90 | 50.64 |
| 16 | 1944 | 67.76 | 66.88 | 63.32 | 62.40 | 67.60 | 65.91 | 78.70 | 70.98 | 53.46 | 75.07 | 67.07 | 53.89 |
| 17 | 1945 | 64.92 | 62.60 | 64.34 | 63.89 | 71.80 | 68.84 | 75.23 | 63.20 | 50.05 | 88.89 | 67.55 | 52.60 |
| 18 | 1946 | 58.93 | 57.83 | 58.75 | 61.17 | 70.36 | 65.91 | 48.82 | 52.22 | 51.95 | 65.02 | 56.65 | 49.64 |
| 19 | 1947 | 65.64 | 64.63 | 69.60 | 64.65 | 75.27 | 66.69 | 69.24 | 60.16 | 53.39 | 72.71 | 64.43 | 48.93 |
| 20 | 1948 | 46.41 | 57.26 | 57.04 | 59.51 | 72.58 | 67.07 | 58.07 | 29.75 | 21.00 | 72.23 | 52.35 | 47.01 |
| 21 | 1949 | 54.25 | 58.44 | 62.84 | 62.85 | 68.95 | 67.91 | 61.17 | 45.48 | 56.38 | 84.95 | 75.03 | 51.85 |
| 22 | 1950 | 60.53 | 58.36 | 57.89 | 63.30 | 71.69 | 62.59 | 54.96 | 65.96 | 22.67 | 43.93 | 58.96 | 52.96 |
| 23 | 1951 | 51.40 | 56.43 | 69.82 | 59.28 | 59.83 | 62.96 | 51.11 | 54.53 | 51.33 | 59.12 | 61.55 | 49.87 |
| 24 | 1952 | 49.22 | 59.06 | 60.42 | 63.93 | 77.00 | 65.91 | 47.81 | 36.95 | 52.84 | 68.98 | 60.42 | 51.12 |
| 25 | 1953 | 66.97 | 62.35 | 63.67 | 63.04 | 73.04 | 73.06 | 81.21 | 60.11 | 22.64 | 64.64 | 60.93 | 49.93 |
| 26 | 1954 | 60.29 | 59.47 | 60.43 | 63.75 | 74.54 | 65.92 | 66.76 | 55.26 | 37.51 | 43.86 | 52.80 | 45.06 |
| 27 | 1955 | 62.11 | 65.70 | 59.47 | 58.18 | 67.94 | 70.27 | 71.30 | 61.68 | 33.52 | 48.19 | 61.81 | 50.30 |
| 28 | 1956 | 50.05 | 59.02 | 68.74 | 55.25 | 70.89 | 62.49 | 38.27 | 44.04 | 23.23 | 64.92 | 55.16 | 47.87 |
| 29 | 1957 | 53.10 | 54.57 | 58.73 | 57.09 | 65.14 | 65.22 | 56.07 | 32.39 | 23.81 | 73.15 | 60.30 | 48.05 |
| 30 | 1958 | 66.62 | 61.68 | 60.04 | 61.48 | 71.51 | 68.05 | 66.29 | 44.07 | 45.61 | 79.38 | 63.65 | 50.31 |
| 31 | 1959 | 58.24 | 64.51 | 61.74 | 60.10 | 70.71 | 64.99 | 61.21 | 60.72 | 39.58 | 59.78 | 53.40 | 43.24 |
| 32 | 1960 | 43.19 | 60.21 | 63.72 | 63.53 | 70.09 | 71.56 | 51.21 | 68.35 | 47.87 | 75.28 | 61.46 | 51.70 |
| 33 | 1961 | 69.32 | 59.39 | 62.18 | 63.41 | 71.91 | 65.03 | 64.87 | 54.94 | 39.59 | 81.51 | 63.70 | 50.99 |
| 34 | 1962 | 63.87 | 58.54 | 60.10 | 57.52 | 72.21 | 75.34 | 56.62 | 65.47 | 49.40 | 78.73 | 57.60 | 49.84 |
| 35 | 1963 | 56.07 | 65.10 | 61.29 | 60.28 | 73.14 | 71.06 | 69.12 | 60.24 | 46.47 | 67.32 | 57.82 | 47.86 |
| 36 | 1964 | 58.22 | 57.38 | 60.89 | 59.59 | 70.88 | 64.38 | 66.05 | 55.75 | 18.55 | 52.49 | 56.14 | 48.10 |
| 37 | 1965 | 51.89 | 60.49 | 64.78 | 57.29 | 62.03 | 61.05 | 62.51 | 51.36 | 51.82 | 72.74 | 48.38 | 49.94 |
| 38 | 1966 | 56.74 | 60.23 | 57.55 | 56.73 | 71.27 | 67.98 | 68.32 | 67.59 | 54.30 | 68.56 | 66.01 | 52.94 |
| 39 | 1967 | 62.24 | 59.35 | 55.73 | 66.18 | 74.24 | 67.24 | 70.90 | 63.91 | 24.49 | 65.55 | 58.18 | 50.25 |
| 40 | 1968 | 52.83 | 60.56 | 58.12 | 59.45 | 73.08 | 65.51 | 131.33 | 62.40 | 45.20 | 67.85 | 56.73 | 46.51 |
| 41 | 1969 | 49.72 | 61.03 | 61.08 | 63.17 | 76.36 | 67.32 | 40.42 | 46.78 | 53.75 | 70.32 | 61.36 | 49.13 |
| 42 | 1970 | 60.99 | 57.04 | 57.17 | 62.75 | 74.15 | 67.82 | 89.24 | 57.08 | 41.28 | 81.98 | 66.53 | 49.15 |
| 43 | 1971 | 63.31 | 57.16 | 58.91 | 61.66 | 61.02 | 62.84 | 55.42 | 38.94 | 12.33 | 62.41 | 53.68 | 46.72 |
| 44 | 1972 | 53.06 | 58.13 | 55.09 | 55.92 | 72.37 | 32.58 | 50.22 | 49.57 | 17.35 | 57.93 | 55.85 | 48.51 |
| 45 | 1973 | 54.56 | 60.51 | 55.91 | 56.79 | 66.57 | 65.58 | 80.15 | 67.20 | 52.13 | 73.20 | 70.14 | 52.29 |
| 46 | 1974 | 61.91 | 60.58 | 60.21 | 47.75 | 63.58 | 50.78 | 38.89 | 54.19 | 18.75 | 44.32 | 59.93 | 50.54 |
| 47 | 1975 | 67.81 | 60.01 | 58.89 | 59.71 | 72.30 | 64.38 | 67.51 | 59.28 | 25.58 | 50.64 | 57.77 | 47.68 |
| 48 | 1976 | 49.59 | 61.15 | 64.44 | 59.67 | 72.93 | 66.33 | 51.71 | 44.13 | 48.28 | 57.57 | 47.71 | 44.56 |
| 49 | 1977 | 57.89 | 62.63 | 61.24 | 60.79 | 68.83 | 70.18 | 81.84 | 69.76 | 54.92 | 82.40 | 71.22 | 53.89 |
| 50 | 1978 | 67.12 | 63.87 | 59.51 | 58.35 | 67.81 | 64.98 | 62.43 | 63.13 | 51.36 | 69.55 | 64.95 | 46.48 |
| 51 | 1979 | 62.03 | 61.79 | 65.50 | 60.24 | 70.84 | 67.82 | 74.48 | 56.60 | 58.84 | 85.59 | 72.06 | 53.47 |
| 52 | 1980 | 61.07 | 63.05 | 64.32 | 58.92 | 69.69 | 67.31 | 60.91 | 39.73 | 47.90 | 75.41 | 65.30 | 47.63 |
| 53 | 1981 | 61.76 | 59.64 | 62.37 | 66.84 | 77.64 | 70.66 | 80.73 | 61.81 | 34.80 | 70.10 | 56.21 | 48.75 |
| 54 | 1982 | 60.74 | 57.96 | 58.85 | 64.64 | 70.18 | 45.94 | 62.62 | 56.34 | 31.85 | 48.01 | 59.80 | 48.43 |
| 55 | 1983 | 54.47 | 61.68 | 56.17 | 59.67 | 75.99 | 54.00 | 69.91 | 61.95 | 51.60 | 58.19 | 58.20 | 48.97 |
| 56 | 1984 | 62.36 | 65.77 | 56.91 | 61.51 | 75.57 | 65.87 | 61.77 | 64.32 | 31.57 | 68.80 | 60.21 | 47.89 |
| 57 | 1985 | 54.04 | 60.83 | 60.55 | 58.52 | 67.60 | 68.36 | 64.58 | 60.99 | 55.90 | 84.47 | 78.90 | 53.09 |
| 58 | 1986 | 53.97 | 63.11 | 57.52 | 62.39 | 71.89 | 46.17 | 54.98 | 66.28 | 49.30 | 82.99 | 66.14 | 50.00 |
| 59 | 1987 | 63.74 | 56.90 | 60.30 | 57.35 | 69.25 | 64.62 | 68.06 | 57.91 | 58.28 | 82.66 | 74.63 | 52.59 |
| 60 | 1988 | 68.45 | 63.09 | 63.51 | 65.88 | 74.32 | 68.06 | 71.92 | 71.32 | 53.19 | 68.81 | 67.65 | 52.56 |
| 61 | 1989 | 66.46 | 60.31 | 62.16 | 63.25 | 84.15 | 69.29 | 58.95 | 66.74 | 54.94 | 75.11 | 70.94 | 52.57 |
| 62 | 1990 | 65.73 | 62.19 | 58.07 | 62.26 | 72.27 | 67.86 | 63.65 | 66.33 | 46.25 | 65.27 | 59.37 | 52.07 |
| 63 | 1991 | 63.65 | 60.75 | 56.05 | 64.55 | 73.61 | 64.63 | 63.67 | 62.77 | 50.80 | 56.58 | 58.12 | 52.16 |
| 64 | 1992 | 65.44 | 60.11 | 62.27 | 58.64 | 69.90 | 68.51 | 74.26 | 65.99 | 61.30 | 87.52 | 68.06 | 53.70 |
| 65 | 1993 | 72.30 | 60.80 | 62.24 | 61.24 | 81.68 | 65.91 | 70.27 | 57.53 | 52.09 | 72.21 | 63.44 | 50.29 |
| 66 | 1994 | 68.41 | 58.82 | 60.80 | 62.02 | 69.86 | 68.51 | 69.88 | 64.74 | 58.76 | 74.63 | 73.51 | 49.93 |
| 67 | 1995 | 66.43 | 59.04 | 60.03 | 60.91 | 74.22 | 66.36 | 84.30 | 59.49 | 41.66 | 79.18 | 65.59 | 50.57 |
| 68 | 1996 | 50.07 | 57.33 | 56.95 | 47.79 | 53.10 | 35.56 | 45.07 | 57.28 | 42.80 | 65.70 | 60.87 | 49.04 |
| 69 | 1997 | 63.35 | 61.50 | 59.05 | 48.45 | 55.84 | 45.99 | 35.92 | 28.46 | 20.63 | 53.71 | 55.47 | 46.10 |
| 70 | 1998 | 46.77 | 56.67 | 62.01 | 59.11 | 74.48 | 67.42 | 69.39 | 49.21 | 44.71 | 66.41 | 56.54 | 50.49 |
| 71 | 1999 | 63.07 | 59.03 | 57.54 | 62.07 | 71.81 | 50.82 | 60.27 | 59.93 | 35.42 | 50.57 | 53.35 | 52.45 |
| 72 | 2000 | 63.50 | 64.73 | 61.16 | 62.20 | 70.73 | 67.35 | 52.41 | 62.76 | 58.59 | 66.21 | 65.39 | 49.34 |
| 73 | 2001 | 69.10 | 63.31 | 62.70 | 61.11 | 71.20 | 70.56 | 86.26 | 72.84 | 57.26 | 75.49 | 70.15 | 54.18 |
| 74 | 2002 | 72.68 | 65.38 | 60.39 | 58.83 | 69.78 | 64.40 | 60.81 | 62.65 | 41.44 | 62.56 | 61.34 | 52.66 |
| 75 | 2003 | 65.63 | 61.88 | 63.32 | 57.83 | 69.67 | 66.18 | 67.05 | 62.94 | 45.18 | 80.48 | 76.94 | 52.75 |
| 76 | 2004 | 63.72 | 59.93 | 59.23 | 56.93 | 68.61 | 67.74 | 67.90 | 69.02 | 54.30 | 77.56 | 69.23 | 49.68 |
| 77 | 2005 | 52.53 | 56.67 | 54.75 | 57.42</ | | | | | | | | |

Table 4.6
Graveyard Market Prices for FY 2022 by Month and Water Year
(\$/MWh)

| | A | B | C | D | E | F | G | H | I | J | K | L | M |
|-----------|------------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|
| | Water Year | Oct-21 | Nov-21 | Dec-21 | Jan-22 | Feb-22 | Mar-22 | Apr-22 | May-22 | Jun-22 | Jul-22 | Aug-22 | Sep-22 |
| 1 | 1929 | 25.81 | 28.76 | 31.51 | 28.67 | 28.43 | 27.73 | 26.33 | 21.54 | 16.10 | 25.48 | 28.28 | 30.69 |
| 2 | 1930 | 25.46 | 30.09 | 31.97 | 29.41 | 29.44 | 27.17 | 28.96 | 21.70 | 18.53 | 23.58 | 27.55 | 30.33 |
| 3 | 1931 | 26.22 | 29.58 | 30.42 | 28.64 | 27.07 | 26.74 | 26.81 | 21.49 | 18.41 | 24.33 | 27.84 | 29.11 |
| 4 | 1932 | 26.33 | 29.86 | 33.03 | 30.59 | 31.42 | 28.93 | 24.56 | 10.15 | -5.67 | 23.26 | 26.86 | 31.98 |
| 5 | 1933 | 30.22 | 29.91 | 31.72 | 25.60 | 25.43 | 26.96 | 28.32 | 17.95 | -19.25 | -2.41 | 22.46 | 28.11 |
| 6 | 1934 | 26.23 | 22.33 | 13.13 | 2.38 | 13.26 | 20.32 | 9.34 | 10.74 | 13.20 | 21.14 | 29.29 | 31.63 |
| 7 | 1935 | 29.12 | 35.38 | 32.92 | 24.89 | 25.56 | 27.00 | 27.75 | 20.76 | 15.65 | 19.30 | 24.60 | 27.19 |
| 8 | 1936 | 24.84 | 29.48 | 31.10 | 30.08 | 30.37 | 29.70 | 28.08 | -0.64 | 6.91 | 23.51 | 30.24 | 31.85 |
| 9 | 1937 | 26.35 | 30.47 | 32.82 | 30.26 | 29.36 | 28.73 | 27.56 | 22.74 | 17.05 | 24.84 | 28.67 | 30.52 |
| 10 | 1938 | 24.49 | 28.44 | 29.75 | 24.68 | 27.79 | 25.14 | 21.31 | 11.12 | 5.24 | 18.52 | 30.09 | 34.49 |
| 11 | 1939 | 27.87 | 32.26 | 32.83 | 28.96 | 28.11 | 28.35 | 27.67 | 16.75 | 18.35 | 21.90 | 28.01 | 29.77 |
| 12 | 1940 | 26.71 | 28.31 | 31.63 | 27.14 | 29.16 | 28.35 | 26.86 | 21.44 | 19.30 | 24.22 | 28.32 | 32.07 |
| 13 | 1941 | 25.93 | 28.90 | 31.36 | 28.85 | 28.39 | 27.61 | 26.97 | 21.65 | 16.88 | 24.11 | 27.63 | 30.38 |
| 14 | 1942 | 24.76 | 28.79 | 26.87 | 26.44 | 26.92 | 26.11 | 27.03 | 19.90 | 5.13 | 19.82 | 27.26 | 27.00 |
| 15 | 1943 | 25.21 | 30.03 | 31.41 | 22.92 | 25.44 | 28.98 | 0.29 | 14.55 | -10.90 | -0.11 | 29.57 | 35.29 |
| 16 | 1944 | 29.64 | 32.78 | 32.09 | 28.87 | 27.66 | 27.67 | 27.77 | 23.46 | 18.89 | 23.86 | 27.65 | 29.80 |
| 17 | 1945 | 24.60 | 27.93 | 30.16 | 28.83 | 28.99 | 28.53 | 29.35 | 19.59 | 2.54 | 27.19 | 31.62 | 29.58 |
| 18 | 1946 | 27.13 | 28.98 | 30.44 | 26.26 | 27.20 | 26.74 | 14.08 | 3.07 | 1.60 | 15.63 | 27.00 | 27.97 |
| 19 | 1947 | 27.45 | 30.40 | 24.55 | 17.93 | 17.19 | 25.00 | 23.95 | 11.72 | 4.53 | 16.43 | 25.65 | 29.35 |
| 20 | 1948 | 19.01 | 26.72 | 29.30 | 21.53 | 25.27 | 27.91 | 27.70 | -14.15 | -19.41 | 19.79 | 20.00 | 28.47 |
| 21 | 1949 | 23.87 | 28.21 | 31.13 | 24.49 | 27.38 | 25.18 | 21.53 | -5.72 | 10.36 | 21.84 | 28.36 | 30.97 |
| 22 | 1950 | 27.17 | 28.86 | 29.55 | 18.21 | 24.52 | 17.28 | 18.66 | 17.64 | -18.98 | -17.79 | 22.39 | 29.94 |
| 23 | 1951 | 24.03 | 25.03 | 23.67 | 5.06 | -1.43 | 16.39 | 15.69 | 6.54 | 5.38 | 3.57 | 27.83 | 31.23 |
| 24 | 1952 | 22.68 | 31.00 | 29.63 | 20.59 | 23.86 | 27.15 | 14.76 | -9.08 | 4.70 | 18.44 | 27.66 | 30.41 |
| 25 | 1953 | 29.12 | 31.07 | 32.79 | 28.00 | 17.22 | 28.98 | 28.92 | 18.62 | -18.78 | 7.68 | 25.54 | 26.74 |
| 26 | 1954 | 26.94 | 29.81 | 30.16 | 21.05 | 20.77 | 25.30 | 25.22 | 8.49 | -9.17 | -13.80 | 16.17 | 26.72 |
| 27 | 1955 | 26.11 | 25.51 | 29.57 | 26.97 | 28.26 | 28.05 | 28.35 | 21.32 | -14.77 | -10.83 | 24.67 | 29.97 |
| 28 | 1956 | 28.23 | 25.70 | 24.07 | 4.02 | 17.22 | 22.05 | 2.34 | -7.84 | -19.94 | 5.52 | 23.79 | 28.69 |
| 29 | 1957 | 27.76 | 30.32 | 29.37 | 26.32 | 27.71 | 27.44 | 22.73 | -13.87 | -18.22 | 23.38 | 24.78 | 28.49 |
| 30 | 1958 | 27.12 | 30.75 | 31.64 | 25.26 | 25.98 | 28.56 | 28.58 | -3.56 | -5.86 | 25.37 | 30.01 | 29.99 |
| 31 | 1959 | 26.60 | 26.81 | 25.27 | 14.11 | 17.74 | 26.55 | 26.14 | 19.16 | -12.26 | 0.90 | 25.72 | 22.82 |
| 32 | 1960 | 9.31 | 22.00 | 27.62 | 25.30 | 25.67 | 26.92 | 19.43 | 19.26 | 0.61 | 20.66 | 29.43 | 32.29 |
| 33 | 1961 | 26.95 | 29.90 | 31.59 | 21.55 | 27.00 | 24.82 | 26.98 | 15.02 | -10.61 | 23.82 | 25.24 | 29.40 |
| 34 | 1962 | 28.19 | 30.25 | 32.50 | 27.90 | 24.69 | 25.67 | 23.69 | 16.67 | 1.68 | 22.88 | 27.93 | 31.05 |
| 35 | 1963 | 26.52 | 27.29 | 25.59 | 24.54 | 21.79 | 28.47 | 28.30 | 20.18 | 3.22 | 22.16 | 26.03 | 29.23 |
| 36 | 1964 | 24.92 | 29.41 | 31.56 | 28.06 | 27.77 | 27.57 | 27.53 | 15.53 | -19.64 | -7.11 | 25.65 | 28.29 |
| 37 | 1965 | 25.19 | 27.67 | 22.17 | 5.34 | -1.84 | 16.26 | 24.28 | 1.29 | -0.99 | 15.59 | 21.99 | 28.24 |
| 38 | 1966 | 28.94 | 33.72 | 32.74 | 26.59 | 26.77 | 29.12 | 26.34 | 21.59 | 10.92 | 19.49 | 27.29 | 28.78 |
| 39 | 1967 | 24.71 | 28.94 | 28.64 | 18.07 | 14.79 | 27.36 | 26.32 | 17.23 | -17.62 | 6.65 | 22.21 | 27.03 |
| 40 | 1968 | 26.40 | 28.22 | 30.48 | 22.03 | 25.19 | 24.15 | 27.18 | 19.10 | -0.58 | 18.94 | 24.99 | 26.27 |
| 41 | 1969 | 24.07 | 24.18 | 28.34 | 11.28 | 19.18 | 27.66 | 3.15 | -3.11 | 0.72 | 18.07 | 28.05 | 31.46 |
| 42 | 1970 | 29.28 | 31.06 | 33.42 | 25.73 | 21.46 | 26.58 | 27.94 | 17.07 | -12.95 | 26.92 | 26.89 | 28.24 |
| 43 | 1971 | 24.49 | 28.72 | 30.14 | 8.11 | -2.23 | 17.85 | 18.71 | -8.84 | -20.98 | -4.59 | 21.73 | 28.06 |
| 44 | 1972 | 27.30 | 29.37 | 29.37 | 4.75 | 15.45 | -18.16 | 11.43 | -4.41 | -20.60 | -5.29 | 19.58 | 28.08 |
| 45 | 1973 | 25.96 | 30.88 | 30.28 | 26.58 | 27.89 | 28.84 | 29.00 | 23.24 | 20.22 | 25.19 | 28.62 | 33.13 |
| 46 | 1974 | 26.79 | 27.98 | 27.03 | -11.09 | -1.18 | -0.90 | 3.37 | 1.45 | -20.40 | -17.99 | 17.82 | 27.49 |
| 47 | 1975 | 26.77 | 31.39 | 32.84 | 24.81 | 24.75 | 25.68 | 26.62 | 14.39 | -17.68 | -5.41 | 26.12 | 32.01 |
| 48 | 1976 | 23.28 | 23.01 | 14.79 | 10.76 | 15.63 | 24.91 | 17.40 | -5.42 | -4.46 | -2.18 | 7.45 | 24.99 |
| 49 | 1977 | 31.87 | 32.80 | 34.61 | 30.42 | 27.89 | 28.21 | 29.71 | 22.24 | 20.32 | 27.92 | 30.07 | 32.25 |
| 50 | 1978 | 25.42 | 29.34 | 30.04 | 27.55 | 29.22 | 29.26 | 23.95 | 16.25 | 8.51 | 16.89 | 28.63 | 26.91 |
| 51 | 1979 | 26.96 | 31.25 | 32.57 | 28.36 | 28.55 | 28.26 | 27.44 | 14.39 | 17.18 | 21.68 | 27.33 | 29.64 |
| 52 | 1980 | 26.83 | 30.57 | 31.75 | 27.72 | 29.04 | 28.46 | 27.40 | -4.64 | -4.68 | 23.63 | 30.92 | 32.16 |
| 53 | 1981 | 27.26 | 30.73 | 25.37 | 20.15 | 22.23 | 29.18 | 28.82 | 19.64 | -11.76 | 16.84 | 25.32 | 29.43 |
| 54 | 1982 | 24.45 | 27.57 | 28.14 | 19.06 | 7.45 | -4.79 | 26.08 | 6.61 | -15.18 | -11.83 | 21.62 | 26.83 |
| 55 | 1983 | 25.94 | 31.72 | 29.75 | 12.87 | 22.88 | -1.28 | 27.90 | 15.68 | 3.57 | -2.14 | 22.71 | 30.07 |
| 56 | 1984 | 27.13 | 23.10 | 29.89 | 16.17 | 22.63 | 25.26 | 25.71 | 17.97 | -14.30 | 10.75 | 26.22 | 30.86 |
| 57 | 1985 | 25.15 | 29.01 | 30.84 | 27.07 | 27.87 | 28.93 | 28.44 | 18.53 | 17.44 | 23.32 | 26.45 | 32.68 |
| 58 | 1986 | 23.40 | 26.50 | 30.19 | 27.47 | 23.70 | -8.75 | 21.05 | 18.09 | 0.71 | 23.42 | 29.28 | 31.94 |
| 59 | 1987 | 29.41 | 30.77 | 30.72 | 28.10 | 29.85 | 29.75 | 27.83 | 19.51 | 18.38 | 21.66 | 27.48 | 32.12 |
| 60 | 1988 | 25.16 | 29.67 | 31.78 | 31.71 | 30.56 | 28.99 | 28.24 | 22.76 | 18.77 | 24.07 | 28.04 | 31.09 |
| 61 | 1989 | 25.93 | 28.08 | 29.78 | 27.38 | 27.27 | 26.20 | 24.38 | 18.82 | 16.47 | 20.22 | 26.64 | 30.87 |
| 62 | 1990 | 26.91 | 29.24 | 28.25 | 22.71 | 22.91 | 26.44 | 25.29 | 21.88 | 1.45 | 13.75 | 25.91 | 28.40 |
| 63 | 1991 | 27.96 | 23.56 | 29.18 | 21.49 | 16.12 | 24.97 | 25.54 | 16.82 | 7.01 | 0.99 | 22.63 | 27.82 |
| 64 | 1992 | 28.29 | 29.27 | 33.08 | 30.72 | 29.94 | 27.74 | 28.56 | 23.26 | 19.45 | 26.17 | 29.90 | 31.83 |
| 65 | 1993 | 27.66 | 28.73 | 32.91 | 29.17 | 29.61 | 26.18 | 26.98 | 9.04 | 15.75 | 21.13 | 28.02 | 30.61 |
| 66 | 1994 | 26.62 | 30.13 | 31.41 | 29.17 | 29.10 | 27.55 | 27.23 | 19.06 | 18.05 | 23.80 | 28.56 | 30.48 |
| 67 | 1995 | 26.75 | 29.79 | 30.97 | 28.27 | 27.82 | 25.90 | 26.19 | 17.64 | -7.58 | 24.59 | 28.23 | 27.92 |
| 68 | 1996 | 23.34 | 16.36 | -0.01 | -5.53 | -4.80 | -8.98 | 14.57 | 7.09 | -10.91 | 3.26 | 24.67 | 31.16 |
| 69 | 1997 | 31.04 | 30.64 | 28.39 | -7.63 | -6.06 | -7.58 | -5.28 | -14.56 | -20.15 | -6.36 | 23.30 | 29.55 |
| 70 | 1998 | 16.16 | 27.47 | 31.89 | 25.18 | 22.80 | 28.83 | 28.79 | 0.78 | -7.64 | 21.39 | 26.75 | 30.18 |
| 71 | 1999 | 25.48 | 30.55 | 29.16 | 11.49 | 21.08 | -1.59 | 22.85 | 15.14 | -14.09 | -7.87 | 15.58 | 31.04 |
| 72 | 2000 | 34.88 | 26.29 | 27.74 | 24.00 | 27.61 | 26.24 | 18.79 | 17.07 | 16.98 | 19.84 | 30.76 | 31.44 |
| 73 | 2001 | 29.00 | 31.13 | 32.31 | 30.81 | 28.32 | 28.21 | 30.09 | 21.29 | 20.47 | 27.13 | 31.87 | 32.39 |
| 74 | 2002 | 26.77 | 28.55 | 30.43 | 29.15 | 29.85 | 28.21 | 26.52 | 17.93 | -6.40 | 13.36 | 29.72 | 36.07 |
| 75 | 2003 | 26.95</ | | | | | | | | | | | |

Table 4.7
Graveyard Market Prices for FY 2023 by Month and Water Year
(\$/MWh)

| | A | B | C | D | E | F | G | H | I | J | K | L | M |
|----|------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | Water Year | Oct-22 | Nov-22 | Dec-22 | Jan-23 | Feb-23 | Mar-23 | Apr-23 | May-23 | Jun-23 | Jul-23 | Aug-23 | Sep-23 |
| 1 | 1929 | 25.77 | 30.29 | 31.22 | 28.23 | 28.19 | 31.67 | 33.37 | 27.70 | 18.22 | 24.62 | 24.88 | 29.06 |
| 2 | 1930 | 28.09 | 32.41 | 31.62 | 28.25 | 29.02 | 32.75 | 32.41 | 26.41 | 20.58 | 23.28 | 24.44 | 29.61 |
| 3 | 1931 | 27.98 | 31.69 | 33.16 | 28.72 | 29.68 | 31.41 | 31.40 | 27.64 | 20.73 | 22.32 | 26.10 | 29.05 |
| 4 | 1932 | 26.47 | 32.77 | 31.18 | 27.47 | 29.13 | 32.52 | 21.92 | 12.89 | -5.68 | 21.85 | 22.30 | 27.39 |
| 5 | 1933 | 32.56 | 31.39 | 29.62 | 23.32 | 25.54 | 33.64 | 32.44 | 20.45 | -17.71 | -4.28 | 19.85 | 26.68 |
| 6 | 1934 | 24.96 | 19.13 | 10.89 | -0.35 | 13.33 | 24.14 | 11.49 | 12.20 | 20.75 | 22.20 | 24.40 | 29.27 |
| 7 | 1935 | 32.74 | 34.89 | 31.21 | 23.47 | 24.82 | 31.55 | 29.32 | 22.29 | 17.51 | 14.18 | 21.87 | 24.32 |
| 8 | 1936 | 27.48 | 33.76 | 35.19 | 30.73 | 32.80 | 33.79 | 33.92 | 6.37 | 9.38 | 22.90 | 24.97 | 32.27 |
| 9 | 1937 | 28.58 | 32.81 | 31.93 | 29.67 | 29.31 | 32.46 | 33.05 | 26.18 | 19.97 | 23.13 | 24.77 | 29.25 |
| 10 | 1938 | 24.14 | 29.23 | 27.95 | 21.75 | 28.70 | 32.34 | 20.45 | 11.85 | 9.69 | 18.78 | 23.09 | 30.08 |
| 11 | 1939 | 34.82 | 35.15 | 35.51 | 28.03 | 28.83 | 32.25 | 32.17 | 21.88 | 20.41 | 21.93 | 25.93 | 30.89 |
| 12 | 1940 | 28.68 | 32.38 | 31.71 | 27.32 | 29.28 | 31.55 | 30.73 | 24.79 | 23.05 | 21.10 | 25.34 | 28.26 |
| 13 | 1941 | 28.58 | 32.43 | 31.89 | 27.38 | 29.18 | 32.27 | 31.75 | 25.89 | 21.17 | 22.47 | 23.75 | 27.51 |
| 14 | 1942 | 25.26 | 29.11 | 26.26 | 23.81 | 29.46 | 32.33 | 31.85 | 27.79 | 5.54 | 17.95 | 24.33 | 28.52 |
| 15 | 1943 | 25.36 | 31.16 | 29.87 | 22.24 | 23.57 | 30.52 | -5.06 | 18.28 | -8.22 | -1.48 | 23.14 | 30.39 |
| 16 | 1944 | 36.20 | 36.09 | 32.49 | 28.99 | 28.48 | 30.62 | 32.67 | 25.90 | 20.79 | 22.28 | 26.64 | 30.09 |
| 17 | 1945 | 26.39 | 33.05 | 32.48 | 29.48 | 29.05 | 32.71 | 31.54 | 26.21 | 6.44 | 27.11 | 24.80 | 30.52 |
| 18 | 1946 | 25.17 | 29.78 | 28.86 | 23.40 | 27.86 | 32.32 | 17.15 | 7.61 | 3.80 | 14.26 | 21.55 | 28.44 |
| 19 | 1947 | 31.85 | 28.82 | 23.97 | 17.33 | 18.37 | 28.96 | 30.33 | 15.93 | 8.39 | 15.95 | 20.79 | 25.97 |
| 20 | 1948 | 19.42 | 24.23 | 26.45 | 15.65 | 23.48 | 31.56 | 28.12 | -12.52 | -18.78 | 18.26 | 18.15 | 24.90 |
| 21 | 1949 | 25.09 | 29.55 | 31.58 | 26.42 | 28.95 | 29.69 | 25.64 | -2.97 | 16.06 | 23.40 | 26.64 | 30.88 |
| 22 | 1950 | 27.11 | 28.69 | 29.24 | 14.90 | 26.25 | 18.96 | 20.45 | 22.29 | -18.71 | -17.21 | 18.00 | 26.00 |
| 23 | 1951 | 24.82 | 19.90 | 19.44 | 6.90 | 0.08 | 15.63 | 17.18 | 10.16 | 7.66 | 2.15 | 22.99 | 26.76 |
| 24 | 1952 | 22.50 | 29.26 | 26.93 | 19.74 | 24.37 | 31.25 | 13.14 | -8.86 | 8.37 | 18.51 | 25.49 | 29.61 |
| 25 | 1953 | 29.09 | 32.38 | 31.43 | 25.74 | 16.25 | 35.42 | 32.44 | 20.18 | -17.55 | 6.15 | 20.58 | 26.17 |
| 26 | 1954 | 27.64 | 29.12 | 28.55 | 16.45 | 22.04 | 31.34 | 28.60 | 10.52 | -10.31 | -15.45 | 9.98 | 21.41 |
| 27 | 1955 | 30.53 | 30.78 | 28.90 | 27.09 | 28.78 | 30.95 | 31.74 | 23.75 | -12.45 | -11.04 | 20.95 | 28.48 |
| 28 | 1956 | 25.41 | 22.99 | 20.46 | 0.84 | 16.80 | 21.24 | 0.56 | -3.14 | -18.92 | 4.67 | 19.71 | 26.54 |
| 29 | 1957 | 25.99 | 27.01 | 25.29 | 24.29 | 26.92 | 31.68 | 25.38 | -11.81 | -17.01 | 21.71 | 20.94 | 26.42 |
| 30 | 1958 | 27.43 | 32.71 | 30.06 | 23.00 | 25.14 | 32.53 | 31.92 | -1.19 | -4.71 | 24.31 | 24.48 | 29.10 |
| 31 | 1959 | 27.43 | 27.87 | 23.34 | 8.48 | 15.48 | 32.46 | 28.54 | 20.94 | -10.40 | 0.29 | 19.49 | 19.59 |
| 32 | 1960 | 10.40 | 22.81 | 28.14 | 24.93 | 25.14 | 33.13 | 18.64 | 22.65 | 1.91 | 19.15 | 21.44 | 29.37 |
| 33 | 1961 | 34.43 | 31.18 | 33.08 | 21.77 | 27.02 | 28.13 | 29.41 | 15.22 | -10.59 | 27.51 | 23.22 | 27.82 |
| 34 | 1962 | 29.34 | 33.03 | 30.95 | 23.72 | 25.30 | 33.22 | 25.62 | 21.82 | 4.96 | 22.49 | 21.16 | 28.11 |
| 35 | 1963 | 28.70 | 29.95 | 24.70 | 25.08 | 21.04 | 33.55 | 30.16 | 23.49 | 4.04 | 19.06 | 20.30 | 26.52 |
| 36 | 1964 | 25.97 | 31.68 | 31.59 | 27.09 | 27.35 | 29.83 | 31.21 | 19.12 | -19.18 | -8.38 | 19.42 | 25.96 |
| 37 | 1965 | 24.77 | 29.14 | 16.43 | 2.44 | -1.03 | 16.89 | 26.50 | 3.97 | 0.20 | 15.20 | 17.40 | 26.32 |
| 38 | 1966 | 30.57 | 32.58 | 30.61 | 25.36 | 26.66 | 31.70 | 33.93 | 26.49 | 14.06 | 18.67 | 23.84 | 28.86 |
| 39 | 1967 | 28.19 | 31.90 | 29.58 | 17.78 | 18.76 | 32.95 | 31.48 | 24.04 | -17.86 | 6.43 | 20.79 | 26.14 |
| 40 | 1968 | 24.90 | 29.60 | 29.26 | 19.42 | 24.64 | 28.69 | 33.77 | 22.11 | 0.15 | 17.91 | 19.85 | 24.58 |
| 41 | 1969 | 24.15 | 25.78 | 27.84 | 10.61 | 19.99 | 30.23 | 2.07 | -0.89 | 2.73 | 20.36 | 25.67 | 30.01 |
| 42 | 1970 | 29.62 | 28.03 | 29.77 | 23.34 | 24.78 | 33.33 | 30.92 | 20.22 | -10.45 | 26.00 | 21.34 | 26.46 |
| 43 | 1971 | 28.02 | 29.58 | 29.90 | 5.92 | -2.74 | 18.00 | 21.69 | -7.68 | -20.32 | -3.94 | 16.58 | 24.97 |
| 44 | 1972 | 25.17 | 27.88 | 27.02 | 3.50 | 16.49 | -16.39 | 12.13 | -0.48 | -19.85 | -6.04 | 17.13 | 26.84 |
| 45 | 1973 | 26.58 | 30.39 | 27.74 | 23.74 | 27.91 | 30.49 | 31.67 | 25.79 | 21.27 | 22.16 | 26.76 | 29.64 |
| 46 | 1974 | 27.19 | 29.91 | 25.12 | -10.05 | 1.63 | -2.69 | 1.42 | 6.42 | -20.08 | -17.63 | 16.08 | 26.37 |
| 47 | 1975 | 32.36 | 31.15 | 29.51 | 22.66 | 25.88 | 31.07 | 30.35 | 18.17 | -16.67 | -8.65 | 20.28 | 25.78 |
| 48 | 1976 | 24.94 | 24.06 | 14.78 | 7.57 | 16.33 | 27.55 | 17.12 | -1.62 | -1.57 | -1.53 | 6.61 | 25.30 |
| 49 | 1977 | 30.50 | 34.27 | 32.54 | 29.99 | 28.42 | 32.27 | 33.08 | 26.68 | 20.58 | 21.97 | 27.99 | 29.94 |
| 50 | 1978 | 26.17 | 31.50 | 29.81 | 24.19 | 28.88 | 32.41 | 28.31 | 17.96 | 12.05 | 14.35 | 21.41 | 26.21 |
| 51 | 1979 | 30.65 | 32.77 | 34.86 | 28.74 | 29.68 | 32.47 | 32.76 | 16.95 | 22.57 | 22.13 | 26.15 | 30.70 |
| 52 | 1980 | 28.80 | 34.45 | 32.68 | 25.07 | 29.45 | 32.38 | 29.74 | -3.20 | -2.38 | 22.62 | 24.89 | 29.19 |
| 53 | 1981 | 30.10 | 28.96 | 20.20 | 20.98 | 21.41 | 33.66 | 30.65 | 20.59 | -12.55 | 15.58 | 18.24 | 24.38 |
| 54 | 1982 | 27.14 | 30.13 | 28.89 | 19.58 | 9.19 | -7.86 | 28.82 | 9.35 | -14.97 | -14.06 | 18.21 | 23.92 |
| 55 | 1983 | 28.97 | 32.28 | 27.01 | 12.05 | 25.39 | -1.16 | 32.88 | 19.84 | 6.99 | -3.03 | 18.33 | 26.03 |
| 56 | 1984 | 32.33 | 23.85 | 27.56 | 14.43 | 24.06 | 24.54 | 28.06 | 21.15 | -14.42 | 7.65 | 19.24 | 26.64 |
| 57 | 1985 | 25.93 | 29.50 | 30.37 | 26.24 | 25.78 | 32.99 | 31.53 | 21.22 | 22.27 | 22.50 | 25.96 | 32.41 |
| 58 | 1986 | 27.01 | 27.84 | 29.26 | 22.19 | 23.93 | -6.84 | 21.53 | 23.34 | 1.86 | 24.34 | 22.28 | 27.90 |
| 59 | 1987 | 30.86 | 29.46 | 29.81 | 26.77 | 28.41 | 32.36 | 32.24 | 20.09 | 25.02 | 21.66 | 25.45 | 28.83 |
| 60 | 1988 | 28.71 | 32.50 | 34.05 | 31.06 | 29.71 | 32.72 | 34.49 | 28.55 | 20.79 | 21.29 | 26.53 | 29.49 |
| 61 | 1989 | 26.87 | 31.83 | 31.75 | 30.04 | 30.07 | 34.17 | 26.31 | 23.69 | 23.00 | 21.37 | 25.49 | 31.23 |
| 62 | 1990 | 31.43 | 31.82 | 26.92 | 21.48 | 23.81 | 31.23 | 30.27 | 25.12 | 1.96 | 12.75 | 20.73 | 27.55 |
| 63 | 1991 | 29.67 | 21.77 | 25.90 | 21.88 | 17.41 | 30.64 | 29.01 | 20.84 | 11.64 | -1.55 | 18.89 | 25.18 |
| 64 | 1992 | 30.34 | 33.26 | 32.70 | 29.19 | 29.06 | 32.77 | 32.63 | 26.67 | 23.29 | 23.36 | 26.75 | 30.53 |
| 65 | 1993 | 28.74 | 32.31 | 30.98 | 28.66 | 28.82 | 32.21 | 32.44 | 13.99 | 17.79 | 21.41 | 24.84 | 31.08 |
| 66 | 1994 | 27.88 | 30.94 | 31.51 | 27.60 | 28.94 | 31.94 | 31.57 | 25.60 | 22.14 | 20.74 | 26.77 | 30.25 |
| 67 | 1995 | 27.79 | 31.06 | 32.17 | 28.55 | 28.18 | 30.63 | 34.95 | 20.05 | -8.35 | 25.48 | 23.85 | 28.45 |
| 68 | 1996 | 24.23 | 16.77 | 0.44 | -8.20 | -7.51 | -12.53 | 11.50 | 9.41 | -7.68 | 3.92 | 21.29 | 27.34 |
| 69 | 1997 | 33.29 | 31.09 | 26.86 | -7.66 | -6.26 | -5.31 | -2.19 | -13.77 | -19.49 | -8.82 | 19.74 | 24.37 |
| 70 | 1998 | 16.08 | 25.56 | 30.33 | 25.47 | 24.41 | 32.78 | 29.94 | 4.83 | -5.24 | 19.56 | 20.94 | 28.56 |
| 71 | 1999 | 30.39 | 32.48 | 28.35 | 9.55 | 19.39 | -2.68 | 26.92 | 17.88 | -12.91 | -9.54 | 13.24 | 27.39 |
| 72 | 2000 | 31.21 | 22.74 | 25.01 | 22.04 | 28.06 | 31.24 | 19.15 | 20.73 | 22.49 | 18.55 | 24.03 | 28.40 |
| 73 | 2001 | 31.98 | 34.80 | 32.62 | 28.41 | 29.84 | 32.60 | 33.90 | 27.52 | 21.78 | 24.96 | 28.80 | 28.79 |
| 74 | 2002 | 26.09 | 32.76 | 31.25 | 27.34 | 28.75 | 31.61 | 30.99 | 22.26 | -4.17 | 9.78 | 21.86 | 30.04 |
| 75 | 2003 | 29.92 | 33.74 | 31.40 | 26.99 | 30.03 | 33.13 | 30.28 | 24.76 | 8.37 | 24.42 | 25.80 | 29.30 |
| 76 | 2004 | 29.69 | 31.71 | 30.49 | 27.07 | 29.31 | 32.32 | 31.89 | 26.77 | 19.29 | 22.09 | 24.37 | 29.54 |
| 77 | 2005 | 24.64 | 27.64 | 27.49 | 24.65 | 26.42 | 31.19 | 31.34 | 25.40 | 19.15 | 19.98 | 22.97 | 29.36 |
| 78 | | | | | | | | | | | | | |

Table 4.8
Variable Costs Sub-Categories of
Stand Ready Costs from the GARD Model

| | A | B | C |
|----|--------------------------------------|-----------------------|----------------------|
| | | Annual Average MWh | Annual Average \$ |
| 1 | Energy Shift <i>dec</i> | 354,691 | 6,599,765 |
| 2 | Energy Shift Non-Spinning <i>inc</i> | 245,629 | 4,570,430 |
| 3 | Energy Shift Spinning <i>inc</i> | 147,016 | 2,735,532 |
| 4 | <i>Energy Shift Subtotal:</i> | 747,336 | 13,905,727 |
| | | | |
| 5 | Efficiency Loss <i>dec</i> | 24,882 | (2,935,824) |
| 6 | Efficiency Loss Non-Spinning | 20,498 | (2,418,589) |
| 7 | Efficiency Loss Spinning | 2,796 | (329,899) |
| 8 | <i>Efficiency Subtotal:</i> | 48,175 | (5,684,312) |
| | | | |
| 9 | Spill Losses Non-Spinning | 47,923 | 1,174,391 |
| 10 | Spill Losses Spinning | 97,795 | 2,396,526 |
| 11 | <i>Spill Subtotal:</i> | 145,718 | 3,570,917 |
| | | | |
| 12 | Total | 941,229 | 11,792,332 |

Table 4.9
**Variable Costs Components for Reserves Under 99.7% Level of Service with
 Self Supply of Generation Imbalance**

| | A | B | C |
|---|-----------------------------------|--------------------------------|--------------------------------|
| | Component | Annual Average (MW) | Annual Average (\$) |
| 1 | Regulation Reserve <i>inc</i> | 309 | 1,617,960 |
| 2 | Regulation Reserve <i>dec</i> | 327 | 1,450,595 |
| 3 | Non-Regulation Reserve <i>inc</i> | 371 | 1,948,018 |
| 4 | Non-Regulation Reserve <i>dec</i> | 499 | 2,213,346 |
| 5 | Operating Reserves - Spinning | 237 | 4,562,413 |
| 8 | Total Variable Cost | 917 | 11,792,332 |

Table 4.10
GARD Stand-ready Costs and EIM Cost Offsets

| | A | B | C | D | E | F | G |
|---|-------------------------------------|-----------------------|-----------------------|---------------------------|---------------------------|-----------------------------|----------------|
| | | Regulation <i>inc</i> | Regulation <i>dec</i> | Non-regulation <i>inc</i> | Non-regulation <i>dec</i> | Operating Reserves Spinning | All Reserves |
| 1 | Energy shift | \$ 1,907,927 | \$ 1,710,567 | \$ 2,297,137 | \$ 2,610,016 | \$ 5,380,078 | \$ 13,905,727 |
| 2 | Efficiency | \$ (779,913) | \$ (699,237) | \$ (939,012) | \$ (1,066,909) | \$ (2,199,241) | \$ (5,684,312) |
| 3 | Spill | \$ 489,946 | \$ 439,265 | \$ 589,893 | \$ 670,238 | \$ 1,381,576 | \$ 3,570,917 |
| 4 | Total | \$ 1,617,960 | \$ 1,450,595 | \$ 1,948,018 | \$ 2,213,346 | \$ 4,562,413 | \$ 11,792,332 |
| 5 | 50% Energy Shift Cost Offset | \$ - | \$ - | \$ 1,148,569 | \$ 1,305,008 | \$ - | \$ 2,453,577 |
| 6 | 50% Spill Cost Offset | \$ - | \$ - | \$ 294,946 | \$ 335,119 | \$ - | \$ 630,065 |

Table 4.11
7HA.02 SCCT Frame Annual Costs

| | A | B | C | D | E | F | G | H | I | J |
|----|--|-------------------------|------|--------------------|------------------------|--------------|-----------|------------------------------|--------------------------|------------------------------|
| 1 | | | | Calendar Year | Chained GDP IPD | | | Load Shaping Rate HLH \$/MWh | Demand Shaping Factor | Monthly Demand Rate \$/kW/mo |
| 2 | Start Year of Operation (FY) | 2022 | | 2015 | 104.62 | | Oct | 29.92 | 8.50% | \$ 7.01 |
| 3 | Cost of Debt | 2.42% ^{/1} | | 2016 | 105.72 | | Nov | 31.71 | 9.01% | \$ 7.44 |
| 4 | | | 2017 | 107.71 | | Dec | 38.76 | 11.01% | \$ 9.09 | |
| 5 | Inflation Rate | 1.66% | 2018 | 110.30 | | Jan | 34.29 | 9.74% | \$ 8.04 | |
| 6 | Insurance Rate | 0.25% ^{/2} | 2019 | 112.27 | | Feb | 34.79 | 9.88% | \$ 8.15 | |
| 7 | | | 2020 | 113.63 | | Mar | 27.57 | 7.83% | \$ 6.46 | |
| 8 | Debt Finance Period (years) | 30 ^{/2} | | | | Apr | 20.71 | 5.88% | \$ 4.85 | |
| 9 | Plant Lifecycle (years) | 30 ^{/2} | | 101.66% | 5-year Ave. | May | 16.28 | 4.62% | \$ 3.81 | |
| 10 | | | | | | Jun | 17.15 | 4.87% | \$ 4.02 | |
| 11 | Plant in service 2022 Vintaged Heat Rate Btu/kWh | 8,890 ^{/3} | | | | Jul | 36.83 | 10.46% | \$ 8.63 | |
| 12 | | | | | | Aug | 35.87 | 10.19% | \$ 8.41 | |
| 13 | Eastside Fixed Fuel \$/kW/yr with 10000 Heat Rate 2012\$ | \$ 41.42 ^{/4} | | | | Sep | 28.15 | 8.00% | \$ 6.60 | |
| 14 | Westside Fixed Fuel \$/kW/yr with 10000 Heat Rate 2012\$ | \$ 46.03 ^{/4} | | | | | | | Average \$/kW/mo \$ 6.88 | |
| 15 | Eastside Fixed Fuel \$/kW/yr with 10000 Heat Rate 2022\$ | \$ 48.85 | | | | | | | | |
| 16 | Westside Fixed Fuel \$/kW/yr with 10000 Heat Rate 2022\$ | \$ 54.29 | | | | | | | | |
| 17 | Average of Existing Eastside and Westside with 10000 Heat Rate 2022\$ | \$ 51.57 | | | | | | | | |
| 18 | Average of Existing Eastside and Westside with 8890 Heat Rate 2022\$ | \$ 45.85 | | | | | | | | |
| 19 | | | | | | | | | | |
| 20 | All-in Nominal Capital Cost 7HA.02 SCCT Frame \$/kW | \$ 607.26 ^{/5} | | End of Fiscal Year | Midyear Assessed Value | Debt Payment | Fixed O&M | Insurance | Fixed Fuel | Cash Expense Each Year |
| 21 | Fixed O&M \$/kW/yr 2022\$ | 6.07 ^{/5} | | 2022 | \$ 597.14 | \$28.70 | \$ 6.07 | \$ 1.49 | \$ 45.85 | \$ 82.12 |
| 22 | Fixed Fuel \$/kW/yr | \$ 45.85 | | 2023 | \$ 576.90 | \$28.70 | \$ 6.17 | \$ 1.44 | \$ 46.61 | \$ 82.93 |
| 23 | | | | | | | | | | |
| 24 | | | | | | | | | | |
| 25 | ^{/1} Source BPA FY 2020 Third-Party Tax-Exempt Borrowing Rate Forecast 30-year | | | | | | | | | |
| 26 | ^{/2} Source NWPCC 7th Power Plan Appendix H. | | | | | | | | | |
| 27 | ^{/3} Source NWPCC Microfin Model, Version 0.17 2021 Power Plan draft inputs | | | | | | | | | |
| 28 | ^{/4} Source NWPCC Microfin Model, Version 15.0.5 | | | | | | | | | |
| 29 | ^{/5} Source NWPCC Microfin Model, Version 0.17 2021 Power Plan draft inputs in 2016 dollars | | | | | | | | | |
| 30 | ^{/6} Source BP-22-FS-BPA-01A Power Rates Study Documentation Table 4.1. | | | | | | | | | |

LMS100 Average Expense \$/kW/mo^{/6} \$9.67
7HA.02 SCCT Frame Average Expense \$/kW/mo \$6.88
Expense Delta \$2.80

Table 4.12
Cost of Capacity Calculation

| | A Annual Average of FY2022-FY2022 | B | C |
|----|---|-----------------|-------------------|
| | | No EIM Discount | With EIM Discount |
| 1 | Assumptions for Calculation: | | |
| 2 | Embedded Unit Cost of Capacity | \$ 5.87 | \$ 5.87 |
| 3 | | | |
| 4 | Variable Costs: | | |
| 5 | Regulation inc | \$ 0.44 | \$ 0.26 |
| 6 | Regulation dec | \$ 0.37 | \$ 0.37 |
| 7 | Non-regulation inc | \$ 0.44 | \$ 0.26 |
| 8 | Non-regulation dec | \$ 0.37 | \$ 0.10 |
| 9 | Operating Reserves | \$ 0.80 | \$ 0.80 |
| 10 | | | |
| 11 | Base Cost of Capacity by Reserve Type | | |
| 12 | Regulation inc (Line 2 + 5) | \$ 6.31 | \$ 6.13 |
| 13 | Regulation dec (Line 6) | \$ 0.37 | \$ 0.37 |
| 14 | Non-regulation inc (Line 2 + 7) | \$ 6.31 | \$ 6.13 |
| 15 | Non-regulation dec (Line 8) | \$ 0.37 | \$ 0.10 |
| 16 | Operating Reserves - Spinning and Supplemental (Line 2 + 9) | \$ 6.67 | \$ 6.67 |
| 18 | | | |
| 19 | Rate Design Delta: | | |
| 20 | Inc value delta | \$ 2.80 | \$ 2.80 |
| 21 | Regulation inc weighted value delta | \$ 1.53 | \$ 1.53 |
| 22 | Non-regulation inc weighted value delta | \$ (1.27) | \$ (1.27) |
| 23 | Operating Reserves - Spinning value delta | \$ 1.40 | \$ 1.40 |
| 24 | Operating Reserves - Non Spinning value delta | \$ (1.40) | \$ (1.40) |
| 25 | | | |
| 26 | Total Cost of Capacity by Reserve Type: | | |
| 27 | Regulation inc (Line 12 + 21) | \$ 7.84 | \$ 7.66 |
| 28 | Regulation dec (Line 13) | \$ 0.37 | \$ 0.37 |
| 29 | Non-regulation inc (Line 14 + 22) | \$ 5.04 | \$ 4.86 |
| 30 | Non-regulation dec (Line 15) | \$ 0.37 | \$ 0.10 |
| 31 | Operating Reserves - Spining (Line 16 + 23) | \$ 8.07 | \$ 8.07 |
| 32 | Operating Reserves - Supplemental (Line 16 + 24) | \$ 5.27 | \$ 5.27 |

Table 4.13
Revenue Forecast

| | A | B | C | D |
|----|--|------------------------------------|------------------|--------------------------------|
| 1 | Cost of Capacity by Reserve Type (See Table 4.4) | \$ / kW-mo | | |
| 2 | Regulation inc | \$ 7.84 | | |
| 3 | Regulation dec | \$ 0.37 | | |
| 4 | Non-regulation inc | \$ 5.04 | | |
| 5 | Non-regulation dec | \$ 0.37 | | |
| 6 | Operating Reserves - Spinning | \$ 8.07 | | |
| 7 | Operating Reserves - Supplemental | \$ 5.27 | | |
| 8 | | | | |
| 9 | Operating Reserve Quantity | MW | | |
| 10 | Operating Reserves Spinning | 237 | | |
| 11 | Operating Reserves Supplemental | 237 | | |
| 12 | | | | |
| 13 | Balancing Reserve Quantity | Non-Federal Generation (MW) | Load (MW) | Federal Generation (MW) |
| 14 | Regulation Reserves inc | 140 | 146 | 22.96 |
| 15 | Regulation Reserves dec | 148 | 155 | 24.35 |
| 16 | Non-regulation Reserves inc | 226 | 146 | 0.00 |
| 17 | Non-regulation Reserves dec | 303 | 196 | 0.01 |
| 18 | | | | |
| 19 | Revenue Forecast (\$ in Thousands) | Non-Federal Generation | Load | Federal Generation* |
| 20 | (Cost from A1 * Quantity from A9 or A13 * 12) | | | |
| 21 | Balancing Reserves - Regulation inc | \$13,158 | \$13,709 | \$2,160 |
| 22 | Balancing Reserves - Regulation dec | \$659 | \$686 | \$108 |
| 23 | Balancing Reserves - Non-regulation inc | \$13,650 | \$8,816 | \$0 |
| 24 | Balancing Reserves - Non-regulation dec | \$1,347 | \$870 | \$0 |
| 25 | Balancing Reserves - Total | \$28,814 | \$24,082 | \$2,268 |
| 26 | | | | |
| 27 | Operating Reserves Spinning | \$22,924 | | |
| 28 | Operating Reserves Supplemental | \$14,970 | | |
| 29 | Operating Reserves - Total | \$37,894 | | |
| 30 | | | | |
| 31 | Total Revenue Forecast (B25 + C25 + B29) | \$90,790 | | |
| 32 | | | | |
| 33 | | \$/kW-mo | | |
| 34 | Average Cost of Balancing Reserves ((B25+C25)/((B14+C14+B16+C16)*12)) | \$6.71 | | |
| 35 | Average Cost of Operating Reserves (B29/((B10+B11)*12)) | \$6.67 | | |

*Federal Generation Balancing Costs are not included in the Total Revenue Forecast because these costs are paid for by Power Customers

Table 5.1
Synchronous Condenser Projected Motoring Hours, Hourly Energy Consumption and Energy Costs

| | A | B | C | D | E | F | G | H | I | J |
|----|--|--|--------------------------------------|----------------------------|--------------------------|--------------------------|--------------------------|--|---------------------------------------|--|
| | Generating Project | Nameplate rating (MW/unit) | Motoring power consumption (MW/unit) | Projected Units to be used | Condensing Hours FY 2018 | Condensing Hours FY 2019 | Condensing Hours FY 2020 | Average Annual Condensing hours/year [(E+F+G)/3] | Energy Consumption MWhrs/year [H * C] | Total Cost of Energy [I * Market Price Forecast of energy] |
| 1 | John Day, units 11-14 | 155 | 3.0 | units 11-14 | 1,582 | 4,472 | 4,735 | 3,596 | 10,789 | \$ 293,461 |
| 2 | The Dalles, units 15-20 | 99 | 1.5 | units 15-20 | 870 | 430 | 1,177 | 826 | 1,239 | \$ 33,687 |
| 3 | SUBTOTAL - SOUTHERN INTERTIE* | | | | | | | | 12,028 | \$ 327,148 |
| 4 | Grand Coulee, units 19-24 | 690 (units 19-21) 805 (units 22-24) | 11.0 | units 19-21 | 1,160 | 1,224 | 1,168 | 1,184 | 13,024 | \$ 354,253 |
| 5 | Dworshak (small units) | 103 | 4.0 | units 1-2 | 1 | 55 | 0 | 19 | 75 | \$ 2,031 |
| 6 | Dworshak (big unit) | 259 | 8.0 | unit 3 | 0 | 10 | 45 | 18 | 147 | \$ 3,989 |
| 7 | Palisades, units 1-4 | 44 | 0.6 | units 1-4 | 9 | 4,264 | 4,996 | 3,090 | 1,854 | \$ 50,423 |
| 8 | Detroit, units 1-2 | 58 | 2.0 | units 1-2 | NA | NA | NA | 0 | 0 | \$ - |
| 9 | Green Peter, units 1-2 | 46 | 1.2 | units 1-2 | NA | NA | NA | 0 | 0 | \$ - |
| 10 | Lookout Point, units 1-3 | 46 | 1.1 | units 1-3 | NA | NA | NA | 0 | 0 | \$ - |
| 11 | Hungry Horse, units 1-4 | 107 | 2.5 | units 1-4 | 0 | 0 | 0 | 0 | 0 | \$ - |
| 12 | SUBTOTAL - NETWORK* | | | | | | | | 15,099 | \$ 410,696 |
| 13 | TOTAL ENERGY COST | | | | | | | | 27,127 | \$ 737,844 |
| 14 | Market Price Forecast of energy (\$/MWh) | \$ 27.20 | | | | | | | | |

*Synchronous condensing costs for the John Day and The Dalles projects are allocated to the Southern Intertie segment. Costs of all other projects are allocated to the Network segment.

Table 5.2
Determination of Synchronous Condenser Plant Modification Costs*
(\$ thousands)

| | A | B | C | D |
|---|---|--------------|--------------|------------------------------------|
| | | FY 2022 | FY 2023 | Annual Average of FY 2022 - FY2023 |
| 1 | Synchronous Condensers Net Plant | \$ 5,598 | \$ 5,495 | \$ 5,547 |
| 2 | Total Corps/Reclamation Average Net Plant | \$ 6,289,890 | \$ 6,421,851 | \$ 6,355,871 |
| 3 | percent | 0.09% | 0.09% | 0.09% |
| 4 | Corps/Reclamation Net Interest | \$ 25,574 | \$ 21,327 | \$ 23,451 |
| 5 | Sync Cond Net Interest | \$ 23 | \$ 18 | \$ 21 |
| 6 | Corps/Reclamation MRNR | \$ 54,846 | \$ 86,446 | \$ 70,646 |
| 7 | Sync Cond MRNR | \$ 49 | \$ 74 | \$ 62 |
| 8 | Sync Cond Depreciation | \$ 103 | \$ 103 | \$ 103 |
| 9 | Total Sync Cond Plant Modification Costs | \$ 175 | \$ 195 | \$ 185 |

* These are costs for plant modifications at John Day and The Dalles to enable synchronous condenser operation. These costs are allocated to the Southern Intertie segment.

Table 5.3
Summary of Synchronous Condenser Costs
(\\$)

| | A | B | C | D |
|---|---|-------------------|-------------------|-----------------------------------|
| | | FY 2022 | FY 2023 | Annual Average of FY2022 - FY2023 |
| 1 | Modifications at John Day and The Dalles* | \$ 175,000 | \$ 195,000 | \$ 185,000 |
| 2 | Energy Consumption - John Day and The Dalles | \$ 327,148 | \$ 327,148 | \$ 327,148 |
| 3 | Subtotal - Southern Intertie | \$ 502,148 | \$ 522,148 | \$ 512,148 |
| 4 | Energy Consumption - Network | \$ 410,696 | \$ 410,696 | \$ 410,696 |
| 5 | Total Synchronous Condenser Costs | \$ 912,844 | \$ 932,844 | 922,844 |

* These are costs for plant modifications at John Day and The Dalles to enable synchronous condenser operation. These costs are allocated to the Southern Intertie segment.

Table 6.1
ESTIMATED COSTS OF "GENERATION DROP" OF UNIT 22, 23, OR 24 AT THE GRAND COULEE THIRD POWERHOUSE

| | Equipment | Incremental Equipment Deterioration, Replacement or Overhaul Costs | | | Incremental Routine Operation and Maintenance Costs | | | Incremental Lost Revenue In The Event of Replacement or Overhaul | | | | Total Cost Per Drop |
|---|---|--|----------------------------|------------|---|-----------------|-----------|--|--------------------|-------------------|------------|---------------------|
| | | % Life Reduction Per Drop | Cost of Major Overhaul (1) | Cost/Drop | % Increase O&M Per Drop | Annual O&M Cost | Cost/Drop | Probability of Failure | Months of Downtime | Downtime Cost (2) | Cost/Drop | |
| | A | B | C | D | E | F | G | H | I | J | K | L |
| 1 | 550kV Circuit Breaker (50% of replacement) | 0.04% | \$ 865,000 | \$ 346 | 0.04% | \$ 5,375 | \$ 2 | 0.04% | 1 | \$ 1,178,667 | \$ 471 | \$ 820 |
| 2 | Main Power Transformer (equal to replacement) | 0.015% | \$ 9,872,937 | \$ 1,481 | 0.015% | \$ 62,087 | \$ 9 | 0.018% | 1 | \$ 1,178,667 | \$ 212 | \$ 1,702 |
| 3 | Generator (rewinding) | 0.71% | \$ 21,971,000 | \$ 155,994 | 0.71% | \$ 489,483 | \$ 3,475 | 0.71% | 18 | \$ 21,216,000 | \$ 150,634 | \$ 310,103 |
| 4 | Turbine (refurbished) | 0.24% | \$ 1,730,000 | \$ 4,152 | 0.24% | \$ 489,483 | \$ 1,175 | 0.05% | 16 | \$ 18,858,667 | \$ 9,429 | \$ 14,756 |
| 5 | 500 kV Cable (replacement) | 0.055% | \$ 6,508,260 | \$ 3,580 | 0.055% | \$ 306,502 | \$ 169 | 0.055% | 1 | \$ 1,178,667 | \$ 648 | \$ 4,396 |
| 6 | Total Cost Per Drop | | | \$ 165,553 | | | \$ 4,830 | | | | \$ 161,395 | \$ 331,778 |
| 7 | Total Generation Dropping Cost per year (3) | | | \$ 364,955 | | | | | | | | |

(1) Updated to FY 2022-FY 2023 from original Harza Engineering Company study using the Handy-Whitman Index to calculate cost multiplier

1.73

(2) The downtime cost from last unit out at Coulee analysis, assumes normal unit availability at Coulee and then the loss of an additional big unit. The current Value of Availability is adjusted to forecasted average market price for energy (\$27.20) during the FY 2022-2023 rate period. This analysis assumes that the overhauls in the Nathaniel Washington Third Powerplant are completed prior to FY2022-2023.

(3) Drops per year 1.1

Table 7.1 Redispatch Costs FY 2016 to August 2020

| | Fiscal Year | Discretionary | NT Redispatch: Transmission Purchases | NT Redispatch: FCRPS Redispatch (INC/DEC) | Emergency | Total |
|----|---------------------------------|---------------|---|--|-----------|-------------|
| | A | B | C | D | E | F |
| 1 | 2011 | \$11,355 | \$470,500 | \$0 | \$0 | \$481,855 |
| 2 | 2012 | \$35,858 | \$528,192 | \$0 | \$74,690 | \$638,740 |
| 3 | 2013 | \$93,574 | \$259,862 | \$254 | \$788 | \$354,478 |
| 4 | 2014 | \$62,646 | \$84,886 | \$0 | \$24,458 | \$171,990 |
| 5 | 2015 | \$12,309 | \$40,605 | \$4,932 | \$0 | \$57,846 |
| 6 | 2016 | \$15,551 | \$128,615 | \$9,100 | \$22,117 | \$175,383 |
| 7 | 2017 | \$8,136 | \$152,392 | \$1,381 | \$0 | \$161,909 |
| 8 | 2018 | \$15,133 | \$887,672 | \$0 | \$0 | \$902,804 |
| 9 | 2019 | \$16,033 | \$286,534 | \$0 | \$0 | \$302,568 |
| 10 | 2020 (through Aug) | \$0 | \$243,385 | \$9,100 | \$0 | \$252,485 |
| 11 | Total FY2016-2020 (Aug): | \$54,853 | \$1,698,598 | \$19,581 | \$22,117 | \$1,795,149 |
| 12 | FY Average: | \$11,157 | \$345,478 | \$3,983 | \$4,498 | \$377,926 |
| 13 | FY22-23 Forecast: | \$11,000 | \$355,000 | \$4,000 | \$0 | \$370,000 |

Table 8.1
Load Factor Calculation for Station Service Energy Use Analysis

| | Substation Name | Installed Transformation (kVA) | Historical Average Monthly Use (kWh) | Calculated Load Factor |
|----|------------------------|---------------------------------------|---|-------------------------------|
| | A | B | C | D |
| 1 | Large | | | |
| 2 | Alvey | 2,267 | 96,923 | |
| 3 | Bell | 2,250 | 149,000 | |
| 4 | Snohomish | 1,250 | 78,000 | |
| 5 | Olympia | 1,100 | 132,738 | |
| 6 | Covington | 946 | 108,333 | |
| 7 | Pearl | 875 | 28,067 | |
| 8 | Longview | 825 | 38,317 | |
| 9 | McNary | 800 | 108,717 | |
| 10 | Chemawa | 725 | 18,140 | |
| 11 | Anaconda | 600 | 42,910 | |
| 12 | Columbia | 600 | 18,292 | |
| 13 | John Day | 500 | 65,896 | |
| 14 | Santiam | 400 | 25,740 | |
| 15 | St. Johns | 310 | 15,858 | |
| 16 | Port Angeles | 300 | 49,920 | |
| 17 | Valhalla | 300 | 17,592 | |
| 18 | Fairview | 300 | 12,560 | |
| 19 | Subtotal | 14,348 | 1,007,003 | |
| | | | | |
| 20 | Medium | | | |
| 21 | Oregon City | 225 | 13,663 | |
| 22 | Walla Walla | 150 | 6,919 | |
| 23 | LaGrande | 150 | 5,663 | |
| 24 | Ellensburg | 100 | 3,897 | |
| 25 | Roundup | 75 | 5,708 | |
| 26 | Boardman | 75 | 1,595 | |
| 27 | Drain | 65 | 1,654 | |
| 28 | Reedsport | 55 | 3,922 | |
| 29 | Subtotal | 895 | 43,021 | |
| | | | | |
| 30 | Small | | | |
| 31 | Sappho | 45 | 2,363 | |
| 32 | Lookout Point | 40 | 3,387 | |
| 33 | The Dalles | 38 | 2,657 | |
| 34 | Bandon | 25 | 1,746 | |
| 35 | Gardiner | 25 | 1,402 | |
| 36 | Creston | 15 | 1,122 | |
| 37 | Hauser | 10 | 1,525 | |
| 38 | Duckabush | 10 | 1,192 | |
| 39 | Ione | 5 | 1,028 | |
| 40 | Subtotal | 213 | 16,422 | |
| 41 | TOTAL | 15,456 | 1,066,446 | 9.452% |

Calculated Load Factor is the Historical Average Monthly Use divided by Installed Transformation divided by 730 average hours in the month.

$$D = C / B / 730.$$

Table 8.2
Calculation of Station Service Use and Cost

| | Facility Type | Installed Transformation (kVA) | Average Monthly Use¹ (kWh) | Annual Station Service Use² (MWh) | Transmission Losses³ (MWh) | Annual Average Market Price Forecast (\$/MWh) | Real Power Losses Capacity Charge (\$/MWh) | Cost Allocation for Station Service per Year⁴ (\$) |
|---|-------------------------|---------------------------------------|--|---|--|--|---|--|
| | A | B | C | D | E | F | G | H |
| 1 | Large | 40,253 | 2,777,376 | | | | | |
| 2 | Medium | 5,998 | 413,855 | | | | | |
| 3 | Small | 1,448 | 99,910 | | | | | |
| 4 | Big Eddy/Celilo Complex | | 1,822,937 | | | | | |
| 5 | Ross Complex | | 1,749,300 | | | | | |
| 6 | Total | 47,699 | 6,863,378 | 82,361 | 1,680 | \$27.20 | \$ 5.52 | \$ 2,295,181 |

1/ For Large, Medium and Small substations, the calculated average monthly use is installed transformation times 9.452% average calculated load factor times 730 average hours in month (B * 0.09452% * 730). Historical usage is metered for Big Eddy/Celilo and Ross Complexes.

2/ Annual Station Service Use is the Average Monthly Use times 12 months divided by 1000 to convert from kWh to MWh.

3/ Transmission Losses associated with Annual Station Service is based on the BPA Transmission Network Loss Factor of 2.04% (D * 0.0204)

4/ Cost Allocation for Station Service per Year is the sum of (i) the amount of Annual Station Service Use plus Transmission Losses multiplied by the Annual Average Market Price Forecast ((D+E)*F); and (ii) Transmission Losses multiplied by the Real Power Losses Capacity Rate (E*G).

